

Trenco
818 Soundside Rd
Edenton, NC 27932

Re: 25-3407-B
25-5068-A RVF-LOT 36 ROOF

The truss drawing(s) referenced below have been prepared by Truss Engineering Co. under my direct supervision based on the parameters provided by Riverside Roof Truss.

Pages or sheets covered by this seal: I76046211 thru I76046234

My license renewal date for the state of North Carolina is December 31, 2025.

North Carolina COA: C-0844




September 3, 2025

Galinski, John

IMPORTANT NOTE: The seal on these truss component designs is a certification that the engineer named is licensed in the jurisdiction(s) identified and that the designs comply with ANSI/TPI 1. These designs are based upon parameters shown (e.g., loads, supports, dimensions, shapes and design codes), which were given to MiTek or TRENCO. Any project specific information included is for MiTek's or TRENCO's customers file reference purpose only, and was not taken into account in the preparation of these designs. MiTek or TRENCO has not independently verified the applicability of the design parameters or the designs for any particular building. Before use, the building designer should verify applicability of design parameters and properly incorporate these designs into the overall building design per ANSI/TPI 1, Chapter 2.

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	GE01	Common Supported Gable	1	1	176046211

Riverside Roof Truss, LLC, Danville, Va - 24541, 8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:03:57 2025 Page 1
ID:Bxl2MwYau_NHkbraGCmHloyOvst-1TgL9WYGe5Ae4fpiMDen6wLD6qZKxaYVCndjZOyhiOW



LOADING (psf)	SPACING-	CSI.	DEFL.	in	(loc)	l/defl	L/d	PLATES	GRIP
TCLL (roof) 20.0	2-0-0	TC 0.09	Vert(LL)	-0.00	9	n/r	120	MT20	244/190
Snow (Pf/Pg) 11.6/15.0	Plate Grip DOL 1.15	BC 0.03	Vert(CT)	-0.00	9	n/r	120		
TCDL 10.0	Lumber DOL 1.15	WB 0.04	Horz(CT)	0.00	10	n/a	n/a		
BCLL 0.0 *	Rep Stress Incr YES	Matrix-S							
BCDL 10.0	Code IRC2018/TPI2014							Weight: 67 lb	FT = 20%

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.2	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.2	BOT CHORD Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS 2x4 SP No.3	
OTHERS 2x4 SP No.3	

REACTIONS. All bearings 11-7-0.
(lb) - Max Horz 16=109(LC 15)
Max Uplift All uplift 100 lb or less at joint(s) 16, 10, 14, 15, 12, 11
Max Grav All reactions 250 lb or less at joint(s) 16, 10, 13, 14, 15, 12, 11

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

NOTES-

- Unbalanced roof live loads have been considered for this design.
- Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=2ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Corner(3E) -1-0-0 to 1-9-8, Exterior(2N) 1-9-8 to 5-9-8, Corner(3R) 5-9-8 to 8-9-8, Exterior(2N) 8-9-8 to 12-7-0 zone; cantilever left and right exposed; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- Truss designed for wind loads in the plane of the truss only. For studs exposed to wind (normal to the face), see Standard Industry Gable End Details as applicable, or consult qualified building designer as per ANSI/TPI 1.
- TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
- Unbalanced snow loads have been considered for this design.
- This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
- All plates are 2x4 MT20 unless otherwise indicated.
- Gable requires continuous bottom chord bearing.
- Truss to be fully sheathed from one face or securely braced against lateral movement (i.e. diagonal web).
- Gable studs spaced at 2-0-0 oc.
- This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
- Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 16, 10, 14, 15, 12, 11.
- This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3, 2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M01	MONOPITCH	6	1	176046212

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:03:58 2025 Page 1

ID:Bxl2MwYau_NHkbraGcmHloyOvst-WgDjNsZuPPJUhpOuvx90e8uJ7EqcgvWfR0MG5qyhiOV




Plate Offsets (X,Y)-- [2:0-2-5,0-0-5]									
LOADING (psf)		SPACING-		CSI.		DEFL.		PLATES	
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.39	Vert(LL)	-0.03 6-7 >999 240	MT20	244/190
Snow (Pf/Pg)	11.6/15.0	Lumber DOL	1.15	BC	0.34	Vert(CT)	-0.06 6-7 >999 180		
TCDL	10.0	Rep Stress Incr	YES	WB	0.51	Horz(CT)	0.01 6 n/a n/a		
BCLL	0.0 *	Code IRC2018/TPI2014		Matrix-MS					
BCDL	10.0							Weight: 59 lb	FT = 20%

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD	2x4 SP No.2	BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS	2x4 SP No.3		
SLIDER	Left 2x4 SP No.3 2-6-0		

REACTIONS. (size) 2=0-3-8, 6=Mechanical
Max Horz 2=148(LC 15)
Max Uplift 2=-56(LC 16), 6=-31(LC 16)
Max Grav 2=523(LC 2), 6=458(LC 2)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-4=-660/179
BOT CHORD 2-7=-273/666, 6-7=-273/666
WEBS 4-6=-698/233

NOTES-

- Unbalanced roof live loads have been considered for this design.
- Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) -1-0-0 to 2-0-0, Interior(1) 2-0-0 to 11-6-4 zone; cantilever left and right exposed; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
- Unbalanced snow loads have been considered for this design.
- This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
- This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
- Refer to girder(s) for truss to truss connections.
- Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 2, 6.
- This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3,2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacompnents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M01GE	MONOPITCH SUPPORTED	1	1	176046213

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:03:58 2025 Page 1

ID:Bxl2MwYau_NHkbraGCmHloyOvst-WgDjNsZuPPJUhpuv90e8uMSEusg0bfR0MG5qyhiOV




Plate Offsets (X,Y)-- [2:0-1-8,0-0-5]									
LOADING (psf)		SPACING-		CSI.		DEFL.		PLATES	
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.24	Vert(LL)	-0.00 1 n/r 120	MT20	244/190
Snow (Pf/Pg)	11.6/15.0	Lumber DOL	1.15	BC	0.07	Vert(CT)	-0.00 1 n/r 120		
TCDL	10.0	Rep Stress Incr	YES	WB	0.05	Horz(CT)	0.00 9 n/a n/a		
BCLL	0.0 *	Code	IRC2018/TPI2014	Matrix-S				Weight: 61 lb	FT = 20%
BCDL	10.0								

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 6'-0" oc purlins, except end verticals.
BOT CHORD	2x4 SP No.2	BOT CHORD	Rigid ceiling directly applied or 10'-0" oc bracing.
WEBS	2x4 SP No.3		
OTHERS	2x4 SP No.3		
SLIDER	Left 2x4 SP No.3 1'-7"-8"		

REACTIONS. All bearings 11-8-0.
(lb) - Max Horz 2=146(LC 13)
Max Uplift All uplift 100 lb or less at joint(s) 9, 2, 10, 11, 12, 13, 14
Max Grav All reactions 250 lb or less at joint(s) 9, 2, 10, 11, 12, 13, 14

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-3=-340/173, 3-4=-261/141

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCdL=6.0psf; BCdL=6.0psf; h=25ft; B=45ft; L=24ft; eave=2ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Corner(3E) -1'-0" to 2'-0", Exterior(2N) 2'-0" to 11'-6" zone; cantilever left and right exposed; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - Truss designed for wind loads in the plane of the truss only. For studs exposed to wind (normal to the face), see Standard Industry Gable End Details as applicable, or consult qualified building designer as per ANSI/TPI 1.
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
 - All plates are 2x4 MT20 unless otherwise indicated.
 - Gable requires continuous bottom chord bearing.
 - Gable studs spaced at 2'-0" oc.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3'-6" tall by 2'-0" wide will fit between the bottom chord and any other members.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 9, 2, 10, 11, 12, 13, 14.
 - Beveled plate or shim required to provide full bearing surface with truss chord at joint(s) 2.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3, 2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacompnents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate
818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M02	HALF HIP	3	1	176046214

Riverside Roof Truss, LLC, Danville, Va - 24541,


8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:03:59 2025 Page 1

ID:Bxl2MwYau_NHkbraGCmHloyOvst_sn5aCaWaiRLJzz5TegFBLQYHdE8PTxofg6pdGyhiOU

-1-0-0
1-0-0

2-8-0
2-8-0

3-8-0
1-0-0



LOADING (psf)	SPACING-	CSI.	DEFL.	in	(loc)	I/defl	L/d	PLATES	GRIP
TCLL (roof) 20.0	2-0-0	TC 0.18	Vert(LL)	-0.00	10	>999	240	MT20	244/190
Snow (Pf/Pg) 16.5/15.0	Plate Grip DOL 1.15	BC 0.07	Vert(CT)	-0.00	7	>999	180		
TCDL 10.0	Lumber DOL 1.15	WB 0.05	Horz(CT)	0.00	2	n/a	n/a		
BCLL 0.0 *	Rep Stress Incr NO	Matrix-MP							
BCDL 10.0	Code IRC2018/TPI2014							Weight: 19 lb	FT = 20%

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.2	TOP CHORD
BOT CHORD 2x6 SP No.2	Structural wood sheathing directly applied or 3-8-0 oc purlins, except end verticals, and 2-0-0 oc purlins: 4-7, 4-5.
WEBS 2x4 SP No.3	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.

REACTIONS. (size) 2=0-3-8, 6=Mechanical
Max Horz 2=42(LC 13)
Max Uplift 2=-8(LC 16)
Max Grav 2=263(LC 36), 6=325(LC 3)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) -1-0-0 to 2-0-0, Interior(1) 2-0-0 to 3-6-4 zone; cantilever left and right exposed ; end vertical left and right exposed;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=16.5 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10, Lu=50-0-0; Min. flat roof snow load governs. Rain surcharge applied to all exposed surfaces with slopes less than 0.500/12 in accordance with IBC 1608.3.4.
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
 - Provide adequate drainage to prevent water ponding.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Refer to girder(s) for truss to truss connections.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 2.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.
 - Load case(s) 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52 has/have been modified. Building designer must review loads to verify that they are correct for the intended use of this truss.
 - Graphical purlin representation does not depict the size or the orientation of the purlin along the top and/or bottom chord.

LOAD CASE(S) Standard
1) Dead + Snow (balanced): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-43, 6-8=-20, 4-5=-83



September 3,2025

Continued on page 2

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate
818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M02	HALF HIP	3	1	176046214

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:03:59 2025 Page 2
ID:Bxl2MwYau_NHkbraGCmHloyOvst-_sn5aCaWaiRLJzz5TegFBLQYHdE8PTxofg6pdGyhiOU

- LOAD CASE(S)** Standard
- Concentrated Loads (lb)
Vert: 13=-160
- 2) Dead + Roof Live (balanced): Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-60, 6-8=-20, 4-5=-90
- Concentrated Loads (lb)
Vert: 13=-160
- 3) Dead + 0.75 Roof Live (balanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-50, 6-8=-20, 4-5=-139
- Concentrated Loads (lb)
Vert: 13=-160
- 4) Dead + 0.75 Snow (balanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-37, 6-8=-20, 4-5=-133
- Concentrated Loads (lb)
Vert: 13=-160
- 5) Dead + 0.75 Snow (Unbal. Left) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-11=-37, 3-11=-42, 6-8=-20, 4-5=-114
- Concentrated Loads (lb)
Vert: 13=-160
- 6) Dead + 0.75 Snow (Unbal. Right) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-25, 6-8=-20, 4-5=-135
- Concentrated Loads (lb)
Vert: 13=-160
- 7) Dead + Uninhabitable Attic Without Storage: Lumber Increase=1.25, Plate Increase=1.25
- Uniform Loads (plf)
Vert: 1-3=-20, 6-8=-40, 4-5=-50
- Concentrated Loads (lb)
Vert: 13=-160
- 8) Dead + 0.6 C-C Wind (Pos. Internal) Case 1: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=60, 2-12=50, 3-12=34, 6-8=-12, 4-5=16
Horz: 1-2=-72, 2-12=-62, 3-12=-46, 3-4=10, 5-6=38
- Concentrated Loads (lb)
Vert: 13=-160
- 9) Dead + 0.6 C-C Wind (Pos. Internal) Case 2: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=45, 2-3=50, 6-8=-12, 4-5=32
Horz: 1-2=-57, 2-3=-62, 3-4=-51, 5-6=-24
- Concentrated Loads (lb)
Vert: 13=-160
- 10) Dead + 0.6 C-C Wind (Neg. Internal) Case 1: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=1, 2-3=-46, 6-8=-20, 4-5=-64
Horz: 1-2=-21, 2-3=26, 3-4=-30, 5-6=-35
- Concentrated Loads (lb)
Vert: 13=-160
- 11) Dead + 0.6 C-C Wind (Neg. Internal) Case 2: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-41, 2-3=-46, 6-8=-20, 4-5=-64
Horz: 1-2=21, 2-3=26, 3-4=31, 5-6=27
- Concentrated Loads (lb)
Vert: 13=-160
- 12) Dead + 0.6 MWFRS Wind (Pos. Internal) Left: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=28, 2-3=13, 6-8=-12, 4-5=8
Horz: 1-2=-40, 2-3=-25, 3-4=-11, 5-6=18
- Concentrated Loads (lb)
Vert: 13=-160
- 13) Dead + 0.6 MWFRS Wind (Pos. Internal) Right: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=3, 2-3=8, 6-8=-12, 4-5=8
Horz: 1-2=-15, 2-3=-20, 3-4=-26, 5-6=-15
- Concentrated Loads (lb)
Vert: 13=-160
- 14) Dead + 0.6 MWFRS Wind (Neg. Internal) Left: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-16, 2-3=-21, 6-8=-20, 4-5=-39
Horz: 1-2=-4, 2-3=1, 3-4=31, 5-6=7
- Concentrated Loads (lb)
Vert: 13=-160
- 15) Dead + 0.6 MWFRS Wind (Neg. Internal) Right: Lumber Increase=1.60, Plate Increase=1.60

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M02	HALF HIP	3	1	176046214
					Job Reference (optional)

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:03:59 2025 Page 3
ID:Bxl2MwYau_NHkbraGCmHloyOvst-_sn5aCaWaiRLJzz5TegFBLQYHdE8PTxofg6pdGyhiOU

LOAD CASE(S) Standard

- Uniform Loads (plf)
Vert: 1-2=-5, 2-3=-10, 6-8=-20, 4-5=-39
Horz: 1-2=-15, 2-3=-10, 3-4=-4, 5-6=-25
- Concentrated Loads (lb)
Vert: 13=-160
- 16) Dead + 0.6 MWFRS Wind (Pos. Internal) 1st Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=32, 2-3=17, 6-8=-12, 4-5=-1
Horz: 1-2=-44, 2-3=-29, 3-4=-34, 5-6=23
Concentrated Loads (lb)
Vert: 13=-160
- 17) Dead + 0.6 MWFRS Wind (Pos. Internal) 2nd Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=21, 2-3=6, 6-8=-12, 4-5=-12
Horz: 1-2=-33, 2-3=-18, 3-4=-24, 5-6=23
Concentrated Loads (lb)
Vert: 13=-160
- 18) Dead + 0.6 MWFRS Wind (Neg. Internal) 1st Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-16, 2-3=-21, 6-8=-20, 4-5=-39
Horz: 1-2=-4, 2-3=1, 3-4=6, 5-6=12
Concentrated Loads (lb)
Vert: 13=-160
- 19) Dead + 0.6 MWFRS Wind (Neg. Internal) 2nd Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-16, 2-3=-21, 6-8=-20, 4-5=-39
Horz: 1-2=-4, 2-3=1, 3-4=6, 5-6=12
Concentrated Loads (lb)
Vert: 13=-160
- 20) Dead + Snow on Overhangs: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-2=-43, 2-3=-20, 6-8=-20, 4-5=-50
Concentrated Loads (lb)
Vert: 13=-160
- 21) Dead + Snow (Unbal. Left): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-11=-43, 3-11=-49, 6-8=-20, 4-5=-57
Concentrated Loads (lb)
Vert: 13=-160
- 22) Dead + Snow (Unbal. Right): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-27, 6-8=-20, 4-5=-85
Concentrated Loads (lb)
Vert: 13=-160
- 23) Dead: Lumber Increase=0.90, Plate Increase=0.90 Plt. metal=0.90
Uniform Loads (plf)
Vert: 1-3=-20, 6-8=-20, 4-5=-50
Concentrated Loads (lb)
Vert: 13=-160
- 24) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-34, 2-3=-38, 6-8=-20, 4-5=-124
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
Concentrated Loads (lb)
Vert: 13=-160
- 25) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-26, 2-3=-30, 6-8=-20, 4-5=-124
Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
Concentrated Loads (lb)
Vert: 13=-160
- 26) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-34, 2-3=-38, 6-8=-20, 4-5=-124
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 13=-160
- 27) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-34, 2-3=-38, 6-8=-20, 4-5=-124
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 13=-160

Continued on page 4

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacompnents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M02	HALF HIP	3	1	176046214

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:03:59 2025 Page 4
ID:Bxl2MwYau_NHkbraGcmHloyOvst-_sn5aCaWaiRLJzz5TegFBLQYHdE8PTxofg6pdGyhiOU

LOAD CASE(S) Standard

- 28) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-47, 2-3=-51, 6-8=-20, 4-5=-129
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
Concentrated Loads (lb)
Vert: 13=-160
- 29) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-39, 2-3=-43, 6-8=-20, 4-5=-129
Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
Concentrated Loads (lb)
Vert: 13=-160
- 30) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-47, 2-3=-51, 6-8=-20, 4-5=-129
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 13=-160
- 31) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-47, 2-3=-51, 6-8=-20, 4-5=-129
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 13=-160
- 32) Dead + Minimum Snow: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-20, 6-8=-20, 4-5=-80
Concentrated Loads (lb)
Vert: 13=-160
- 33) Dead + 0.6 C-C Wind Min. Down: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=4, 2-3=-28, 6-8=-12, 4-5=-46
Horz: 1-2=-16, 2-3=16, 3-4=-16, 5-6=-16
Concentrated Loads (lb)
Vert: 13=-160
- 34) Dead + 0.6 C-C Wind Min. Upward: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-3=4, 6-8=-12, 4-5=-14
Horz: 1-3=-16, 3-4=16, 5-6=16
Concentrated Loads (lb)
Vert: 13=-160
- 35) 3rd Unbal.Dead + Snow (balanced) + Parallel: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-27, 6-8=-20, 4-5=-100
Concentrated Loads (lb)
Vert: 13=-160
- 36) 4th Unbal.Dead + Snow (balanced) + Parallel: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-70, 6-8=-20, 4-5=-57
Concentrated Loads (lb)
Vert: 13=-160
- 37) 5th Unbal.Dead + 0.75 Snow (balanced) + 0.75 Attic Floor + Parallel: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-25, 6-8=-20, 4-5=-146
Concentrated Loads (lb)
Vert: 13=-160
- 38) 6th Unbal.Dead + 0.75 Snow (balanced) + 0.75 Attic Floor + Parallel: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-57, 6-8=-20, 4-5=-114
Concentrated Loads (lb)
Vert: 13=-160
- 39) 7th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-22, 2-3=-26, 6-8=-20, 4-5=-137
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
Concentrated Loads (lb)
Vert: 13=-160
- 40) 8th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-54, 2-3=-58, 6-8=-20, 4-5=-105
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
Concentrated Loads (lb)
Vert: 13=-160

Continued on page 5

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacompnents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M02	HALF HIP	3	1	176046214

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:03:59 2025 Page 5
ID:Bxl2MwYau_NHkbraGCmHloyOvst-_sn5aCaWaiRLJzz5TegFBLQYHdE8PTxofg6pdGyhiOU

LOAD CASE(S) Standard

- 41) 9th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-14, 2-3=-18, 6-8=-20, 4-5=-137
Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
Concentrated Loads (lb)
Vert: 13=-160
- 42) 10th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-46, 2-3=-50, 6-8=-20, 4-5=-105
Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
Concentrated Loads (lb)
Vert: 13=-160
- 43) 11th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-22, 2-3=-26, 6-8=-20, 4-5=-137
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 13=-160
- 44) 12th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-54, 2-3=-58, 6-8=-20, 4-5=-105
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 13=-160
- 45) 13th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-22, 2-3=-26, 6-8=-20, 4-5=-137
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 13=-160
- 46) 14th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-54, 2-3=-58, 6-8=-20, 4-5=-105
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 13=-160
- 47) 15th Unbal.Dead + Minimum Snow + Parallel: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-27, 6-8=-20, 4-5=-100
Concentrated Loads (lb)
Vert: 13=-160
- 48) 16th Unbal.Dead + Minimum Snow + Parallel: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-70, 6-8=-20, 4-5=-57
Concentrated Loads (lb)
Vert: 13=-160
- 49) 1st Dead + Roof Live (unbalanced): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-60, 6-8=-20, 4-5=-50
Concentrated Loads (lb)
Vert: 13=-160
- 50) 2nd Dead + Roof Live (unbalanced): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-20, 6-8=-20, 4-5=-90
Concentrated Loads (lb)
Vert: 13=-160
- 51) 3rd Dead + 0.75 Roof Live (unbalanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-50, 6-8=-20, 4-5=-109
Concentrated Loads (lb)
Vert: 13=-160
- 52) 4th Dead + 0.75 Roof Live (unbalanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-20, 6-8=-20, 4-5=-139
Concentrated Loads (lb)
Vert: 13=-160

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)




818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M03	Monopitch	6	1	176046215

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:03:59 2025 Page 1

ID:BxI2MwYau_NHkbraGcmHloyOvst-_sn5aCaWAIrLJzz5TegFBLQYvdE6PTfotg6pdGyhiOU



LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in	(loc)	I/defl	L/d	PLATES	GRIP
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.14				MT20	244/190
Snow (Pf/Pg)	11.6/15.0	Lumber DOL	1.15	BC	0.07					
TCDL	10.0	Rep Stress Incr	YES	WB	0.00					
BCLL	0.0 *	Code IRC2018/TPI2014		Matrix-MP						
BCDL	10.0								Weight: 18 lb	FT = 20%

LUMBER-	BRACING-
TOP CHORD	2x4 SP No.2
BOT CHORD	2x6 SP No.2
WEBS	2x4 SP No.3
	Structural wood sheathing directly applied or 3-8-0 oc purlins, except end verticals.
	Rigid ceiling directly applied or 10-0-0 oc bracing.

REACTIONS. (size) 4=Mechanical, 2=0-3-8
Max Horz 2=53(LC 15)
Max Uplift 4=6(LC 16), 2=43(LC 16)
Max Grav 4=136(LC 21), 2=215(LC 21)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) -1-0-0 to 2-0-0, Interior(1) 2-0-0 to 3-6-4 zone; cantilever left and right exposed ; end vertical left and right exposed;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Refer to girder(s) for truss to truss connections.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 4, 2.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3,2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacompnents.com)


ENGINEERING BY
TRENCO
A MiTek Affiliate
818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M03GE	Monopitch Supported Gable	1	1	176046216

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:00 2025 Page 1

ID:Bxl2MwYau_NHkbraGCmHloyOvst-S2LUoYa8x0ZCx7YH1MBUjZzkW1bF8w?xuKrN9jyhiOT



LOADING (psf)	SPACING-	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL (roof) 20.0	2-0-0	TC 0.08	Vert(LL) -0.00	1	n/r	120	MT20	244/190
Snow (Pl/Pg) 11.6/15.0	Plate Grip DOL 1.15	BC 0.01	Vert(CT) -0.00	1	n/r	120		
TCDL 10.0	Lumber DOL 1.15	WB 0.06	Horz(CT) 0.00	5	n/a	n/a		
BCLL 0.0 *	Rep Stress Incr YES	Matrix-P						
BCDL 10.0	Code IRC2018/TPI2014						Weight: 18 lb	FT = 20%

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.2	TOP CHORD Structural wood sheathing directly applied or 3-8-0 oc purlins, except end verticals.
BOT CHORD 2x6 SP No.2	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS 2x4 SP No.3	
OTHERS 2x4 SP No.3	

REACTIONS. (size) 5=3-8-0, 2=3-8-0, 6=3-8-0
Max Horz 2=52(LC 15)
Max Uplift 5=-3(LC 13), 2=-38(LC 16), 6=-8(LC 16)
Max Grav 5=63(LC 21), 2=135(LC 21), 6=153(LC 21)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

NOTES-

- Unbalanced roof live loads have been considered for this design.
- Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=2ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Corner(3E) -1-0-0 to 2-0-0, Exterior(2N) 2-0-0 to 3-6-4 zone; cantilever left and right exposed ; end vertical left and right exposed;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- Truss designed for wind loads in the plane of the truss only. For studs exposed to wind (normal to the face), see Standard Industry Gable End Details as applicable, or consult qualified building designer as per ANSI/TPI 1.
- TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
- Unbalanced snow loads have been considered for this design.
- This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
- Gable requires continuous bottom chord bearing.
- Gable studs spaced at 2-0-0 oc.
- This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
- Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 5, 2, 6.
- This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3,2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate
818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M04	HALF HIP	3	1	176046217

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:00 2025 Page 1
ID:Bxl2MwYau_NHkbraGCmHloyOvst-S2LUoYa8x0ZCx7YH1MBUjZzYU1X38vPxuKrN9jyhiOT

-1-0-0
1-0-0

6-8-0
6-8-0

7-8-0
1-0-0




Plate Offsets (X,Y)-- [2:0-0-0,0-0-14]									
LOADING (psf)		SPACING-		CSI.		DEFL.		PLATES	
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.85	Vert(LL)	-0.03 7-12 >999 240	MT20	244/190
Snow (Pf/Pg)	16.5/15.0	Lumber DOL	1.15	BC	0.28	Vert(CT)	-0.06 7-12 >999 180		
TCDL	10.0	Rep Stress Incr	NO	WB	0.10	Horz(CT)	0.01 2 n/a n/a		
BCLL	0.0 *	Code	IRC2018/TPI2014	Matrix-MP					
BCDL	10.0							Weight: 38 lb	FT = 20%

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals, and 2-0-0 oc purlins: 4-7, 4-5.
BOT CHORD	2x6 SP No.2	BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS	2x4 SP No.3		
WEDGE			
Left: 2x4 SP No.3			

REACTIONS. (size) 6=Mechanical, 2=0-3-0
Max Horz 2=116(LC 16)
Max Uplift 2=-16(LC 16)
Max Grav 6=467(LC 28), 2=456(LC 36)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
BOT CHORD 6-7=-137/382
WEBS 4-6=-484/164

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional); cantilever left and right exposed ; end vertical left and right exposed; Lumber DOL=1.60 plate grip DOL=1.60
 - C-C wind load user defined.
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=16.5 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10, Lu=50-0-0; Min. flat roof snow load governs. Rain surcharge applied to all exposed surfaces with slopes less than 0.500/12 in accordance with IBC 1608.3.4.
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
 - Provide adequate drainage to prevent water ponding.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Refer to girder(s) for truss to truss connections.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 2.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.
 - Load case(s) 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52 has/have been modified. Building designer must review loads to verify that they are correct for the intended use of this truss.
 - Graphical purlin representation does not depict the size or the orientation of the purlin along the top and/or bottom chord.
 - In the Load CASE(S) section, loads applied to the face of the truss are noted as front (F) or back (B).



September 3,2025

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M04	HALF HIP	3	1	176046217
Job Reference (optional)					

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:00 2025 Page 2
ID:Bxl2MwYau_NHkbraGCmHloyOvst-S2LUoYa8x0ZCx7YH1MBUjZzYU1X38vPxuKrN9jyhiOT

LOAD CASE(S)

- 1) Dead + Snow (balanced): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-43, 4-5=-83(F=-30), 6-8=-20
Concentrated Loads (lb)
Vert: 15=-160
- 2) Dead + Roof Live (balanced): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-60, 4-5=-90(F=-30), 6-8=-20
Concentrated Loads (lb)
Vert: 15=-160
- 3) Dead + 0.75 Roof Live (balanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-50, 4-5=-139(F=-89), 6-8=-20
Concentrated Loads (lb)
Vert: 15=-160
- 4) Dead + 0.75 Snow (balanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-37, 4-5=-133(F=-89), 6-8=-20
Concentrated Loads (lb)
Vert: 15=-160
- 5) Dead + 0.75 Snow (Unbal. Left) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-14=-37, 3-14=-42, 4-5=-114(F=-89), 6-8=-20
Concentrated Loads (lb)
Vert: 15=-160
- 6) Dead + 0.75 Snow (Unbal. Right) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-25, 4-5=-137(F=-89), 6-8=-20
Concentrated Loads (lb)
Vert: 15=-160
- 7) Dead + Uninhabitable Attic Without Storage: Lumber Increase=1.25, Plate Increase=1.25
Uniform Loads (plf)
Vert: 1-3=-20, 4-5=-50(F=-30), 6-8=-40
Concentrated Loads (lb)
Vert: 15=-160
- 8) Dead + 0.6 C-C Wind (Pos. Internal) Case 1: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=58, 2-13=45, 3-13=34, 4-5=16(F=-18), 6-8=-12
Horz: 1-2=-70, 2-13=-57, 3-13=-46, 3-4=7, 5-6=36
Concentrated Loads (lb)
Vert: 15=-160
- 9) Dead + 0.6 C-C Wind (Pos. Internal) Case 2: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=29, 2-13=34, 3-13=45, 4-5=27(F=-18), 6-8=-12
Horz: 1-2=-41, 2-13=-46, 3-13=-57, 3-4=-51, 5-6=-23
Concentrated Loads (lb)
Vert: 15=-160
- 10) Dead + 0.6 C-C Wind (Neg. Internal) Case 1: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-3, 2-3=-42, 4-5=-60(F=-18), 6-8=-20
Horz: 1-2=-17, 2-3=22, 3-4=-30, 5-6=-33
Concentrated Loads (lb)
Vert: 15=-160
- 11) Dead + 0.6 C-C Wind (Neg. Internal) Case 2: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-37, 2-3=-42, 4-5=-60(F=-18), 6-8=-20
Horz: 1-2=17, 2-3=22, 3-4=28, 5-6=25
Concentrated Loads (lb)
Vert: 15=-160
- 12) Dead + 0.6 MWFRS Wind (Pos. Internal) Left: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=28, 2-3=13, 4-5=8(F=-18), 6-8=-12
Horz: 1-2=-40, 2-3=-25, 3-4=-11, 5-6=18
Concentrated Loads (lb)
Vert: 15=-160
- 13) Dead + 0.6 MWFRS Wind (Pos. Internal) Right: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=3, 2-3=8, 4-5=8(F=-18), 6-8=-12
Horz: 1-2=-15, 2-3=-20, 3-4=-26, 5-6=-15
Concentrated Loads (lb)
Vert: 15=-160
- 14) Dead + 0.6 MWFRS Wind (Neg. Internal) Left: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-16, 2-3=-21, 4-5=-39(F=-18), 6-8=-20
Horz: 1-2=-4, 2-3=1, 3-4=31, 5-6=7

Continued on page 3

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M04	HALF HIP	3	1	176046217
Job Reference (optional)					

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:00 2025 Page 3
ID:Bxl2MwYau_NHkbraGCmHloyOvst-S2LUoYa8x0ZCx7YH1MBUjZzYU1X38vPxuKrN9jyhiOT

LOAD CASE(S)

- Concentrated Loads (lb)
Vert: 15=-160
- 15) Dead + 0.6 MWFRS Wind (Neg. Internal) Right: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-5, 2-3=-10, 4-5=-39(F=-18), 6-8=-20
Horz: 1-2=-15, 2-3=-10, 3-4=-4, 5-6=-25
Concentrated Loads (lb)
Vert: 15=-160
- 16) Dead + 0.6 MWFRS Wind (Pos. Internal) 1st Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=32, 2-3=17, 4-5=-1(F=-18), 6-8=-12
Horz: 1-2=-44, 2-3=-29, 3-4=-34, 5-6=23
Concentrated Loads (lb)
Vert: 15=-160
- 17) Dead + 0.6 MWFRS Wind (Pos. Internal) 2nd Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=21, 2-3=6, 4-5=-12(F=-18), 6-8=-12
Horz: 1-2=-33, 2-3=-18, 3-4=-24, 5-6=23
Concentrated Loads (lb)
Vert: 15=-160
- 18) Dead + 0.6 MWFRS Wind (Neg. Internal) 1st Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-16, 2-3=-21, 4-5=-39(F=-18), 6-8=-20
Horz: 1-2=-4, 2-3=1, 3-4=6, 5-6=12
Concentrated Loads (lb)
Vert: 15=-160
- 19) Dead + 0.6 MWFRS Wind (Neg. Internal) 2nd Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-16, 2-3=-21, 4-5=-39(F=-18), 6-8=-20
Horz: 1-2=-4, 2-3=1, 3-4=6, 5-6=12
Concentrated Loads (lb)
Vert: 15=-160
- 20) Dead + Snow on Overhangs: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-2=-43, 2-3=-20, 4-5=-50(F=-30), 6-8=-20
Concentrated Loads (lb)
Vert: 15=-160
- 21) Dead + Snow (Unbal. Left): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-14=-43, 3-14=-49, 4-5=-57(F=-30), 6-8=-20
Concentrated Loads (lb)
Vert: 15=-160
- 22) Dead + Snow (Unbal. Right): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-27, 4-5=-88(F=-30), 6-8=-20
Concentrated Loads (lb)
Vert: 15=-160
- 23) Dead: Lumber Increase=0.90, Plate Increase=0.90 Plt. metal=0.90
Uniform Loads (plf)
Vert: 1-3=-20, 4-5=-50(F=-30), 6-8=-20
Concentrated Loads (lb)
Vert: 15=-160
- 24) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-34, 2-3=-38, 4-5=-124(F=-79), 6-8=-20
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
Concentrated Loads (lb)
Vert: 15=-160
- 25) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-26, 2-3=-30, 4-5=-124(F=-79), 6-8=-20
Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
Concentrated Loads (lb)
Vert: 15=-160
- 26) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-34, 2-3=-38, 4-5=-124(F=-79), 6-8=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 15=-160
- 27) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60

Continued on page 4

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M04	HALF HIP	3	1	176046217

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:00 2025 Page 4
ID:Bxl2MwYau_NHkbraGCmHloyOvst-S2LUoYa8x0ZCx7YH1MBUjZzYU1X38vPxuKrN9jyhiOT

LOAD CASE(S)

- Uniform Loads (plf)
Vert: 1-2=-34, 2-3=-38, 4-5=-124(F=-79), 6-8=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
- Concentrated Loads (lb)
Vert: 15=-160
- 28) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-47, 2-3=-51, 4-5=-129(F=-79), 6-8=-20
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
- Concentrated Loads (lb)
Vert: 15=-160
- 29) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-39, 2-3=-43, 4-5=-129(F=-79), 6-8=-20
Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
- Concentrated Loads (lb)
Vert: 15=-160
- 30) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-47, 2-3=-51, 4-5=-129(F=-79), 6-8=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
- Concentrated Loads (lb)
Vert: 15=-160
- 31) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-47, 2-3=-51, 4-5=-129(F=-79), 6-8=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
- Concentrated Loads (lb)
Vert: 15=-160
- 32) Dead + Minimum Snow: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-20, 4-5=-80(F=-30), 6-8=-20
- Concentrated Loads (lb)
Vert: 15=-160
- 33) Dead + 0.6 C-C Wind Min. Down: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=4, 2-3=-28, 4-5=-46(F=-18), 6-8=-12
Horz: 1-2=-16, 2-3=16, 3-4=-16, 5-6=-16
- Concentrated Loads (lb)
Vert: 15=-160
- 34) Dead + 0.6 C-C Wind Min. Upward: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-3=4, 4-5=-14(F=-18), 6-8=-12
Horz: 1-3=-16, 3-4=16, 5-6=16
- Concentrated Loads (lb)
Vert: 15=-160
- 35) 3rd Unbal.Dead + Snow (balanced) + Parallel: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-27, 4-5=-100(F=-30), 6-8=-20
- Concentrated Loads (lb)
Vert: 15=-160
- 36) 4th Unbal.Dead + Snow (balanced) + Parallel: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-70, 4-5=-57(F=-30), 6-8=-20
- Concentrated Loads (lb)
Vert: 15=-160
- 37) 5th Unbal.Dead + 0.75 Snow (balanced) + 0.75 Attic Floor + Parallel: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-25, 4-5=-146(F=-89), 6-8=-20
- Concentrated Loads (lb)
Vert: 15=-160
- 38) 6th Unbal.Dead + 0.75 Snow (balanced) + 0.75 Attic Floor + Parallel: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-57, 4-5=-114(F=-89), 6-8=-20
- Concentrated Loads (lb)
Vert: 15=-160
- 39) 7th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-22, 2-3=-26, 4-5=-137(F=-79), 6-8=-20
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
- Concentrated Loads (lb)
Vert: 15=-160

Continued on page 5

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M04	HALF HIP	3	1	176046217

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:00 2025 Page 5
ID:Bxl2MwYau_NHkbraGCmHloyOvst-S2LUoYa8x0ZCx7YH1MBUjZzYU1X38vPxuKrN9jyhiOT

LOAD CASE(S)

- 40) 8th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
- Vert: 1-2=-54, 2-3=-58, 4-5=-105(F=-79), 6-8=-20
- Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
- Concentrated Loads (lb)
- Vert: 15=-160
- 41) 9th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
- Vert: 1-2=-14, 2-3=-18, 4-5=-137(F=-79), 6-8=-20
- Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
- Concentrated Loads (lb)
- Vert: 15=-160
- 42) 10th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
- Vert: 1-2=-46, 2-3=-50, 4-5=-105(F=-79), 6-8=-20
- Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
- Concentrated Loads (lb)
- Vert: 15=-160
- 43) 11th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
- Vert: 1-2=-22, 2-3=-26, 4-5=-137(F=-79), 6-8=-20
- Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
- Concentrated Loads (lb)
- Vert: 15=-160
- 44) 12th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
- Vert: 1-2=-54, 2-3=-58, 4-5=-105(F=-79), 6-8=-20
- Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
- Concentrated Loads (lb)
- Vert: 15=-160
- 45) 13th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
- Vert: 1-2=-22, 2-3=-26, 4-5=-137(F=-79), 6-8=-20
- Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
- Concentrated Loads (lb)
- Vert: 15=-160
- 46) 14th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
- Vert: 1-2=-54, 2-3=-58, 4-5=-105(F=-79), 6-8=-20
- Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
- Concentrated Loads (lb)
- Vert: 15=-160
- 47) 15th Unbal.Dead + Minimum Snow + Parallel: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
- Vert: 1-3=-27, 4-5=-100(F=-30), 6-8=-20
- Concentrated Loads (lb)
- Vert: 15=-160
- 48) 16th Unbal.Dead + Minimum Snow + Parallel: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
- Vert: 1-3=-70, 4-5=-57(F=-30), 6-8=-20
- Concentrated Loads (lb)
- Vert: 15=-160
- 49) 1st Dead + Roof Live (unbalanced): Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
- Vert: 1-3=-60, 4-5=-50(F=-30), 6-8=-20
- Concentrated Loads (lb)
- Vert: 15=-160
- 50) 2nd Dead + Roof Live (unbalanced): Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
- Vert: 1-3=-20, 4-5=-90(F=-30), 6-8=-20
- Concentrated Loads (lb)
- Vert: 15=-160
- 51) 3rd Dead + 0.75 Roof Live (unbalanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
- Vert: 1-3=-50, 4-5=-109(F=-89), 6-8=-20
- Concentrated Loads (lb)
- Vert: 15=-160
- 52) 4th Dead + 0.75 Roof Live (unbalanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
- Vert: 1-3=-20, 4-5=-139(F=-89), 6-8=-20
- Concentrated Loads (lb)
- Vert: 15=-160

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.**


Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)



818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF	176046218
25-3407-B	M04SGE	GABLE	1	1	Job Reference (optional)	

Riverside Roof Truss, LLC, Danville, Va - 24541, 8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:01 2025 Page 1
ID:Bxl2MwYau_NHkbraGCmHloyOvst-wFvs?ubmiKh3YG7Tb3jjGmWoQRultNf57_bwi9yhiOS
-1-0-0 6-8-0 7-8-0
1-0-0 6-8-0 1-0-0



LOADING (psf)		SPACING-		CSI.		DEFL.		PLATES		GRIP	
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.52	Vert(LL)	-0.01 8-17 >999 240	MT20		244/190	
Snow (Pf/Pg)	16.5/15.0	Lumber DOL	1.15	BC	0.25	Vert(CT)	-0.01 8-17 >999 180				
TCDL	10.0	Rep Stress Incr	NO	WB	0.03	Horz(CT)	-0.00 2 n/a n/a				
BCLL	0.0 *	Code IRC2018/TPI2014		Matrix-MP							
BCDL	10.0										
								Weight: 41 lb		FT = 20%	

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals, and 2-0-0 oc purlins: 4-7, 4-5.
BOT CHORD	2x6 SP No.2	BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS	2x4 SP No.3		
OTHERS	2x4 SP No.3		
WEDGE			
Left: 2x4 SP No.3			

REACTIONS.	
(size)	6=Mechanical, 2=0-3-0, 8=0-3-8
Max Horz	2=116(LC 16)
Max Uplift	2=28(LC 16)
Max Grav	6=337(LC 28), 2=318(LC 36), 8=286(LC 36)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional); cantilever left and right exposed ; end vertical left and right exposed; Lumber DOL=1.60 plate grip DOL=1.60
 - C-C wind load user defined.
 - Truss designed for wind loads in the plane of the truss only. For studs exposed to wind (normal to the face), see Standard Industry Gable End Details as applicable, or consult qualified building designer as per ANSI/TPI 1.
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=16.5 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10, Lu=50-0-0; Min. flat roof snow load governs. Rain surcharge applied to all exposed surfaces with slopes less than 0.500/12 in accordance with IBC 1608.3.4.
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
 - Provide adequate drainage to prevent water ponding.
 - Gable studs spaced at 2-0-0 oc.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Refer to girder(s) for truss to truss connections.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 2.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.
 - Load case(s) 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52 has/have been modified. Building designer must review loads to verify that they are correct for the intended use of this truss.



September 3,2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacompnents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M04SGE	GABLE	1	1	176046218
Job Reference (optional)					

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:01 2025 Page 2
ID:Bxl2MwYau_NHkbraGCmHloyOvst-wFvs?ubmiKh3YG7Tb3jjGmWoQRultNf57_bwi9yhiOS

LOAD CASE(S)

- 1) Dead + Snow (balanced): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-43, 4-5=-83, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 2) Dead + Roof Live (balanced): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-60, 4-5=-90, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 3) Dead + 0.75 Roof Live (balanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-50, 4-5=-139, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 4) Dead + 0.75 Snow (balanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-37, 4-5=-133, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 5) Dead + 0.75 Snow (Unbal. Left) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-18=-37, 3-18=-42, 4-5=-114, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 6) Dead + 0.75 Snow (Unbal. Right) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-25, 4-5=-137, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 7) Dead + Uninhabitable Attic Without Storage: Lumber Increase=1.25, Plate Increase=1.25
Uniform Loads (plf)
Vert: 1-3=-20, 4-5=-50, 6-13=-40
Concentrated Loads (lb)
Vert: 19=-160
- 8) Dead + 0.6 C-C Wind (Pos. Internal) Case 1: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=61, 2-3=52, 4-5=34, 6-13=-12
Horz: 1-2=-73, 2-3=-64, 3-4=7, 5-6=36
Concentrated Loads (lb)
Vert: 19=-160
- 9) Dead + 0.6 C-C Wind (Pos. Internal) Case 2: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=47, 2-3=52, 4-5=34, 6-13=-12
Horz: 1-2=-59, 2-3=-64, 3-4=-69, 5-6=-23
Concentrated Loads (lb)
Vert: 19=-160
- 10) Dead + 0.6 C-C Wind (Neg. Internal) Case 1: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-3, 2-3=-42, 4-5=-60, 6-13=-20
Horz: 1-2=-17, 2-3=22, 3-4=-48, 5-6=-33
Concentrated Loads (lb)
Vert: 19=-160
- 11) Dead + 0.6 C-C Wind (Neg. Internal) Case 2: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-37, 2-3=-42, 4-5=-60, 6-13=-20
Horz: 1-2=17, 2-3=22, 3-4=28, 5-6=25
Concentrated Loads (lb)
Vert: 19=-160
- 12) Dead + 0.6 MWFRS Wind (Pos. Internal) Left: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=28, 2-3=13, 4-5=8, 6-13=-12
Horz: 1-2=-40, 2-3=-25, 3-4=-11, 5-6=18
Concentrated Loads (lb)
Vert: 19=-160
- 13) Dead + 0.6 MWFRS Wind (Pos. Internal) Right: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=3, 2-3=8, 4-5=8, 6-13=-12
Horz: 1-2=-15, 2-3=-20, 3-4=-26, 5-6=-15
Concentrated Loads (lb)
Vert: 19=-160
- 14) Dead + 0.6 MWFRS Wind (Neg. Internal) Left: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-16, 2-3=-21, 4-5=-39, 6-13=-20
Horz: 1-2=-4, 2-3=1, 3-4=31, 5-6=7

Continued on page 3

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)



818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M04SGE	GABLE	1	1	176046218

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:01 2025 Page 3
ID:Bxl2MwYau_NHkbraGCmHloyOvst-wFvs?ubmiKh3YG7Tb3jjGmWoQRultNf57_bwi9yhiOS

LOAD CASE(S)

- Concentrated Loads (lb)
Vert: 19=-160
- 15) Dead + 0.6 MWFRS Wind (Neg. Internal) Right: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-5, 2-3=-10, 4-5=-39, 6-13=-20
Horz: 1-2=-15, 2-3=-10, 3-4=-4, 5-6=-25
Concentrated Loads (lb)
Vert: 19=-160
- 16) Dead + 0.6 MWFRS Wind (Pos. Internal) 1st Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=32, 2-3=17, 4-5=-1, 6-13=-12
Horz: 1-2=-44, 2-3=-29, 3-4=-34, 5-6=23
Concentrated Loads (lb)
Vert: 19=-160
- 17) Dead + 0.6 MWFRS Wind (Pos. Internal) 2nd Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=21, 2-3=6, 4-5=-12, 6-13=-12
Horz: 1-2=-33, 2-3=-18, 3-4=-24, 5-6=23
Concentrated Loads (lb)
Vert: 19=-160
- 18) Dead + 0.6 MWFRS Wind (Neg. Internal) 1st Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-16, 2-3=-21, 4-5=-39, 6-13=-20
Horz: 1-2=-4, 2-3=1, 3-4=6, 5-6=12
Concentrated Loads (lb)
Vert: 19=-160
- 19) Dead + 0.6 MWFRS Wind (Neg. Internal) 2nd Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-16, 2-3=-21, 4-5=-39, 6-13=-20
Horz: 1-2=-4, 2-3=1, 3-4=6, 5-6=12
Concentrated Loads (lb)
Vert: 19=-160
- 20) Dead + Snow on Overhangs: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-2=-43, 2-3=-20, 4-5=-50, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 21) Dead + Snow (Unbal. Left): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-18=-43, 3-18=-49, 4-5=-57, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 22) Dead + Snow (Unbal. Right): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-27, 4-5=-88, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 23) Dead: Lumber Increase=0.90, Plate Increase=0.90 Plt. metal=0.90
Uniform Loads (plf)
Vert: 1-3=-20, 4-5=-50, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 24) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-34, 2-3=-38, 4-5=-124, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
Concentrated Loads (lb)
Vert: 19=-160
- 25) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-26, 2-3=-30, 4-5=-124, 6-13=-20
Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
Concentrated Loads (lb)
Vert: 19=-160
- 26) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-34, 2-3=-38, 4-5=-124, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 19=-160
- 27) Dead + 0.75 Snow (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60

Continued on page 4

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M04SGE	GABLE	1	1	176046218

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:01 2025 Page 4
ID:Bxl2MwYau_NHkbraGCmHloyOvst-wFvs?ubmiKh3YG7Tb3jGmWoQRultNf57_bwi9yhiOS

LOAD CASE(S)

- Uniform Loads (plf)
Vert: 1-2=-34, 2-3=-38, 4-5=-124, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
- Concentrated Loads (lb)
Vert: 19=-160
- 28) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-47, 2-3=-51, 4-5=-129, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
- Concentrated Loads (lb)
Vert: 19=-160
- 29) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-39, 2-3=-43, 4-5=-129, 6-13=-20
Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
- Concentrated Loads (lb)
Vert: 19=-160
- 30) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-47, 2-3=-51, 4-5=-129, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
- Concentrated Loads (lb)
Vert: 19=-160
- 31) Dead + 0.75 Roof Live (bal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-47, 2-3=-51, 4-5=-129, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
- Concentrated Loads (lb)
Vert: 19=-160
- 32) Dead + Minimum Snow: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-20, 4-5=-80, 6-13=-20
- Concentrated Loads (lb)
Vert: 19=-160
- 33) Dead + 0.6 C-C Wind Min. Down: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=4, 2-3=-28, 4-5=-46, 6-13=-12
Horz: 1-2=-16, 2-3=16, 3-4=-16, 5-6=-16
- Concentrated Loads (lb)
Vert: 19=-160
- 34) Dead + 0.6 C-C Wind Min. Upward: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-3=4, 4-5=-14, 6-13=-12
Horz: 1-3=-16, 3-4=16, 5-6=16
- Concentrated Loads (lb)
Vert: 19=-160
- 35) 3rd Unbal.Dead + Snow (balanced) + Parallel: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-27, 4-5=-100, 6-13=-20
- Concentrated Loads (lb)
Vert: 19=-160
- 36) 4th Unbal.Dead + Snow (balanced) + Parallel: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-70, 4-5=-57, 6-13=-20
- Concentrated Loads (lb)
Vert: 19=-160
- 37) 5th Unbal.Dead + 0.75 Snow (balanced) + 0.75 Attic Floor + Parallel: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-25, 4-5=-146, 6-13=-20
- Concentrated Loads (lb)
Vert: 19=-160
- 38) 6th Unbal.Dead + 0.75 Snow (balanced) + 0.75 Attic Floor + Parallel: Lumber Increase=1.15, Plate Increase=1.15
- Uniform Loads (plf)
Vert: 1-3=-57, 4-5=-114, 6-13=-20
- Concentrated Loads (lb)
Vert: 19=-160
- 39) 7th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
- Uniform Loads (plf)
Vert: 1-2=-22, 2-3=-26, 4-5=-137, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
- Concentrated Loads (lb)
Vert: 19=-160

Continued on page 5

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	M04SGE	GABLE	1	1	176046218

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:01 2025 Page 5
ID:Bxl2MwYau_NHkbraGCmHloyOvst-wFvs?ubmiKh3YG7Tb3jjGmWoQRultNf57_bwi9yhiOS

LOAD CASE(S)

- 40) 8th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Left) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-54, 2-3=-58, 4-5=-105, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=23, 5-6=5
Concentrated Loads (lb)
Vert: 19=-160
- 41) 9th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-14, 2-3=-18, 4-5=-137, 6-13=-20
Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
Concentrated Loads (lb)
Vert: 19=-160
- 42) 10th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) Right) + Parallel: Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-46, 2-3=-50, 4-5=-105, 6-13=-20
Horz: 1-2=-11, 2-3=-7, 3-4=-3, 5-6=-19
Concentrated Loads (lb)
Vert: 19=-160
- 43) 11th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-22, 2-3=-26, 4-5=-137, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 19=-160
- 44) 12th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 1st Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-54, 2-3=-58, 4-5=-105, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 19=-160
- 45) 13th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-22, 2-3=-26, 4-5=-137, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 19=-160
- 46) 14th Unbal.Dead + 0.75 Snow (unbal.) + 0.75 Attic Floor + 0.75(0.6 MWFRS Wind (Neg. Int) 2nd Parallel): Lumber Increase=1.60, Plate Increase=1.60
Uniform Loads (plf)
Vert: 1-2=-54, 2-3=-58, 4-5=-105, 6-13=-20
Horz: 1-2=-3, 2-3=1, 3-4=5, 5-6=9
Concentrated Loads (lb)
Vert: 19=-160
- 47) 15th Unbal.Dead + Minimum Snow + Parallel: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-27, 4-5=-100, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 48) 16th Unbal.Dead + Minimum Snow + Parallel: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-70, 4-5=-57, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 49) 1st Dead + Roof Live (unbalanced): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-60, 4-5=-50, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 50) 2nd Dead + Roof Live (unbalanced): Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-20, 4-5=-90, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 51) 3rd Dead + 0.75 Roof Live (unbalanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-50, 4-5=-109, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160
- 52) 4th Dead + 0.75 Roof Live (unbalanced) + 0.75 Attic Floor: Lumber Increase=1.15, Plate Increase=1.15
Uniform Loads (plf)
Vert: 1-3=-20, 4-5=-139, 6-13=-20
Concentrated Loads (lb)
Vert: 19=-160

 **WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacompnents.com)



818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	T02G	Common Girder	1	3	176046220

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:02 2025 Page 1

ID:BxI2MwYau_NHkbraGCMHloyOvst-ORTECEcOTdpwAQig8mEyp_2r2r9qccrELeKUEbyhiOR

4-4-15 8-6-5 12-7-12 16-9-3 20-10-9 25-3-8

4-4-15 4-1-7 4-1-7 4-1-7 4-1-7 4-4-15





Plate Offsets (X,Y)-- [1:Edge,0-2-0], [7:0-3-8,Edge], [9:0-3-8,0-5-12], [10:0-3-8,0-6-0], [11:0-6-0,0-6-4], [13:0-3-8,0-6-0], [14:0-3-8,0-5-12]									
LOADING (psf)		SPACING-		CSI.		DEFL.		PLATES	
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.97	in (loc)	l/defl	MT20	GRIP
Snow (Pf/Pg)	11.6/15.0	Lumber DOL	1.15	BC	0.45	Vert(LL)	-0.16 10-11 >999		244/190
TCDL	10.0	Rep Stress Incr	NO	WB	0.93	Vert(CT)	-0.30 10-11 >999		
BCLL	0.0 *	Code IRC2018/TPI2014		Matrix-MS		Horz(CT)	0.04 8 n/a n/a		
BCDL	10.0							Weight: 613 lb	FT = 20%

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 4-3-6 oc purlins, except end verticals.
BOT CHORD	2x8 SP DSS	BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS	2x4 SP No.3 *Except*		
	4-11: 2x4 SP No.2, 1-15,1-14,7-8,7-9: 2x4 SP No.1		

REACTIONS. (size) 15=0-3-8, 8=0-3-8
Max Horz 15=-171(LC 10)
Max Uplift 15=-513(LC 12), 8=-456(LC 12)
Max Grav 15=11264(LC 3), 8=13361(LC 3)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 1-2=-15107/688, 2-3=-14142/615, 3-4=-11591/504, 4-5=-11592/504, 5-6=-14922/549, 6-7=-17208/569, 1-15=-9820/456, 7-8=-11164/378
BOT CHORD 14-15=-169/1601, 13-14=-530/12976, 11-13=-396/12186, 10-11=-339/12864, 9-10=-428/14785, 8-9=-75/1910
WEBS 4-11=-431/11394, 5-11=-4909/187, 5-10=-102/5446, 6-10=-2477/113, 6-9=-106/2594, 3-11=-3755/284, 3-13=-214/4128, 2-13=-1043/171, 2-14=-164/1014, 1-14=-454/11564, 7-9=-359/13089

- NOTES-**
- 3-ply truss to be connected together with 10d (0.131"x3") nails as follows:
Top chords connected as follows: 2x4 - 1 row at 0-7-0 oc.
Bottom chords connected as follows: 2x8 - 3 rows staggered at 0-4-0 oc.
Webs connected as follows: 2x4 - 1 row at 0-9-0 oc.
 - All loads are considered equally applied to all plies, except if noted as front (F) or back (B) face in the LOAD CASE(S) section. Ply to ply connections have been provided to distribute only loads noted as (F) or (B), unless otherwise indicated.
 - Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=25ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional); cantilever left and right exposed ; end vertical left and right exposed; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Bearing at joint(s) 15, 8 considers parallel to grain value using ANSI/TPI 1 angle to grain formula. Building designer should verify capacity of bearing surface.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) except (jt=lb) 15=513, 8=456.



September 3,2025

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	T02G	Common Girder	1	3	176046220

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:03 2025 Page 2
ID:Bxl2MwYau_NHkbraGcmHloyOvst-sd1cQad0ExxnoaHsiUIBLBb0oFV3L35Oal41m2yhiOQ

- NOTES-**
- 11) This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.
 - 12) Use Simpson Strong-Tie HUS28 (22-10d Girder, 4-10d Truss) or equivalent spaced at 20-7-8 oc max. starting at 1-11-4 from the left end to 23-11-4 to connect truss(es) to back face of bottom chord.
 - 13) Use Simpson Strong-Tie HUS26 (14-10d Girder, 4-10d Truss) or equivalent spaced at 2-0-0 oc max. starting at 3-11-4 from the left end to 20-6-12 to connect truss(es) to back face of bottom chord.
 - 14) Fill all nail holes where hanger is in contact with lumber.

LOAD CASE(S) Standard

1) Dead + Snow (balanced): Lumber Increase=1.15, Plate Increase=1.15

Uniform Loads (plf)

Vert: 1-4=-43, 4-7=-43, 8-15=-20

Concentrated Loads (lb)

Vert: 16=-1170(B) 17=-1170(B) 18=-1170(B) 19=-1170(B) 20=-1273(B) 21=-1273(B) 22=-1273(B) 23=-1273(B) 24=-1273(B) 25=-1273(B) 26=-1273(B) 27=-1273(B) 28=-1170(B)

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF	176046221
25-3407-B	T02SGE	Common Structural Gable	1	1	Job Reference (optional)	

Riverside Roof Truss, LLC, Danville, Va - 24541, 8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:03 2025 Page 1
ID:BxI2MwYau_NHkbraGcmHloyOvst-sd1cQad0ExxnoaHsiUIBLBb84FTpLA2Oal41m2yhiOQ




Plate Offsets (X,Y)-- [4:0-2-0,0-0-4], [9:0-1-6,0-1-8], [14:0-1-10,0-1-8]									
LOADING (psf)		SPACING-		CSI.		DEFL.		PLATES	
TCLL (roof)	20.0	2-0-0		TC	0.51	in (loc)	l/defl	L/d	GRIP
Snow (Pf/Pg)	11.6/15.0	Plate Grip DOL	1.15	BC	0.60	Vert(LL)	-0.13 8-9 >999	240	244/190
TCDL	10.0	Lumber DOL	1.15	WB	0.49	Vert(CT)	-0.26 8-9 >528	180	
BCLL	0.0 *	Rep Stress Incr	YES	Matrix-MS		Horz(CT)	0.01 8 n/a	n/a	
BCDL	10.0	Code IRC2018/TPI2014							
								Weight: 209 lb	FT = 20%

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD	2x4 SP No.2	BOT CHORD	Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS	2x4 SP No.3	WEBS	1 Row at midpt 4-14
OTHERS	2x4 SP No.3		

REACTIONS. All bearings 14-0-0 except (jt=length) 8=0-3-8, 10=0-3-8.
(lb) - Max Horz 18=189(LC 15)
Max Uplift All uplift 100 lb or less at joint(s) 18, 8, 10 except 14=123(LC 16)
Max Grav All reactions 250 lb or less at joint(s) 11, 13, 15, 16, 17, 10 except 18=327(LC 34), 8=769(LC 29), 14=933(LC 28)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 4-5=-664/168, 5-6=-395/122, 2-18=-306/150, 6-8=-392/133
BOT CHORD 13-14=0/254, 11-13=0/254, 10-11=0/254, 9-10=0/254, 8-9=-19/574
WEBS 4-9=-51/615, 5-9=-315/165, 4-14=-633/23, 3-14=-374/174, 5-8=-427/14

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=25ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) -1-0-0 to 2-0-0, Interior(1) 2-0-0 to 12-7-12, Exterior(2R) 12-7-12 to 15-7-12, Interior(1) 15-7-12 to 26-3-8 zone; cantilever left and right exposed; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - Truss designed for wind loads in the plane of the truss only. For studs exposed to wind (normal to the face), see Standard Industry Gable End Details as applicable, or consult qualified building designer as per ANSI/TPI 1.
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
 - All plates are 2x4 MT20 unless otherwise indicated.
 - Gable studs spaced at 2-0-0 oc.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 18, 8, 10 except (jt=lb) 14=123.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3, 2025


WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacompnents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Riverside Roof Truss, LLC, Danville, Va - 24541, 8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:04 2025 Page 1
 ID:BxI2MwYau_NhKbraGCmHloyOvst-Kqbb_dwd?F3eQkr2GBGQuP7EielV4ZvXppalUyhjOP
 1-0-0 6-7-0 12-10-8 19-2-0 25-5-8 31-9-0 38-4-0 39-4-0
 1-0-0 6-7-0 6-3-8 6-3-8 6-3-8 6-3-8 6-7-0 1-0-0
 Scale = 1:65.8



LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 3-1-4 oc purlins, except end verticals.
BOT CHORD	2x4 SP No.1		
WEBS	2x4 SP No.3	BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing.

REACTIONS.		WEBS	1 Row at midpt	7-15, 5-15, 3-18, 9-12
(size)	18=0-3-8, 12=0-3-8			
Max Horz	18=160(LC 15)			
Max Uplift	18=-128(LC 16), 12=-128(LC 16)			
Max Grav	18=1744(LC 28), 12=1744(LC 29)			

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

TOP CHORD	2-3=-611/102, 3-5=-2859/256, 5-6=-2123/271, 6-7=-2123/271, 7-9=-2859/256, 9-10=-611/102, 2-18=-457/147, 10-12=-457/147
BOT CHORD	17-18=-186/2715, 15-17=-127/2441, 13-15=-111/2383, 12-13=-175/2620
WEBS	6-15=-66/1294, 7-15=-723/136, 7-13=0/483, 5-15=-722/136, 5-17=0/483, 3-18=-2428/187, 9-12=-2428/186

NOTES-

- 1) Unbalanced roof live loads have been considered for this design.
- 2) Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TC DL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=38ft; eave=5ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) -1-0-0 to 2-10-0, Interior(1) 2-10-0 to 19-2-0, Exterior(2R) 19-2-0 to 23-0-0, Interior(1) 23-0-0 to 39-4-0 zone; cantilever left and right exposed ; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- 3) T CLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
- 4) Unbalanced snow loads have been considered for this design.
- 5) This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
- 6) This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- 7) * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
- 8) Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) except (jt=lb) 18=128, 12=128.
- 9) This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3, 2025



WARNING – Verify design parameters and READ NOTES ON THIS AND INCLUDED MITER REFERENCE PAGE MIT-17-15169: 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building design, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TP1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Components Association (www.sbcacomponents.com)



818 Soundside Road
Edenton, NC 27932


Riverside Roof Truss, LLC, Danville, Va - 24541, 8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:05 2025 Page 1

ID:Bxl2MwYau_NHKbraGcMhloyOvst-p09NrGeHmYBV1uQFqvnfQcgPU25op0C2c38rwyhiOO

Diagram showing a roof truss structure with dimensions and member labels. The truss is supported by a wall on the left and a roof on the right. The dimensions are as follows:

- Top chord: 1-0-0, 6-7-0, 12-10-8, 19-2-0, 25-5-8, 31-9-0, 38-0-8
- Bottom chord: 1-0-0, 6-7-0, 6-3-8, 6-3-8, 6-3-8, 6-3-8, 6-3-8

Scale = 1:65.2



REACTIONS. (size) 17=0-3-8, 11=Mechanical
Max Horz 17=161(LC 15)
Max Uplift 17=-128(LC 16), 11=-91(LC 16)
Max Grav 17=1732(LC 28), 11=1673(LC 29)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

TOP CHORD 2-3=-610/102, 3-5=-2835/254, 5-6=-2097/269, 6-7=-2096/271, 7-9=-2786/259,
9-10=-408/63, 2-17=-456/146, 10-11=-295/75

BOT CHORD 16-17=-218/2689, 14-16=-159/2412, 12-14=-143/2334, 11-12=-210/2518

WEBS 5-16=0/484, 5-14=-723/136, 6-14=-66/1273, 7-14=-688/134, 7-12=0/441,
3-17=-2406/185, 9-11=-2535/222

- 1) Unbalanced roof live loads have been considered for this design.
- 2) Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TC DL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=38ft; eave=5ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) -1-0-0 to 2-9-10, Interior(1) 2-9-10 to 19-2-0, Exterior(2R) 19-2-0 to 22-11-10, Interior(1) 22-11-10 to 37-10-12 zone; cantilever left and right exposed ; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
- 3) T CLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
- 4) Unbalanced snow loads have been considered for this design.
- 5) This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
- 6) This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
- 7) * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
- 8) Refer to girder(s) for truss to truss connections.
- 9) Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 11 except (jt=lb) 17=128.
- 10) This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3, 2025



WARNING – Verify design parameters and READ NOTES ON THIS AND INCLUDED MITER REFERENCE PAGE MIT-17-19 (Rev. 1/2/2025) BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building design, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TP1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)



818 Soundside Road
Edenton, NC 27932


Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	T03AGE	Common Supported Gable	1	1	176046224
Job Reference (optional)					

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:06 2025 Page 1
ID:Bxl2MwYau_NHkbraGCmHloyOvst-HCil2bfvXsJMf2?RNcluzqDluSetYckqGGIhNMyhiON

1-0-0 1-0-0 19-2-0 19-2-0 38-0-8 18-10-8

Scale = 1:62.6



LOADING (psf)	SPACING-	CSI.	DEFL.	in (loc)	I/defl	L/d	PLATES	GRIP
TCLL (roof) 20.0	2-0-0	TC 0.09	Vert(LL) -0.00	1	n/r	120	MT20	244/190
Snow (Pf/Pg) 11.6/15.0	Lumber DOL 1.15	BC 0.06	Vert(CT) -0.00	1	n/r	120		
TCDL 10.0	Rep Stress Incr YES	WB 0.17	Horz(CT) 0.00	25	n/a	n/a		
BCLL 0.0 *	Code IRC2018/TPI2014	Matrix-S					Weight: 250 lb	FT = 20%
BCDL 10.0								

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.2	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD 2x4 SP No.2	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing, Except:
WEBS 2x4 SP No.3	6-0-0 oc bracing: 46-47.
OTHERS 2x4 SP No.3	WEBS 1 Row at midpt 13-36

REACTIONS.	All bearings 38-0-8.
(lb) - Max Horz 47=161(LC 15)	
Max Uplift	All uplift 100 lb or less at joint(s) 47, 25, 37, 38, 39, 41, 42, 43, 44, 45, 46, 35, 34, 33, 31, 30, 29, 28, 27, 26
Max Grav	All reactions 250 lb or less at joint(s) 47, 25, 36, 37, 38, 39, 41, 42, 43, 44, 45, 46, 35, 34, 33, 31, 30, 29, 28, 27, 26

FORCES.	(lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD	12-13=-112/277, 13-14=-112/277

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=38ft; eave=2ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Corner(3E) -1-0-0 to 2-9-10, Exterior(2N) 2-9-10 to 19-2-0, Corner(3R) 19-2-0 to 23-2-0, Exterior(2N) 23-2-0 to 37-10-12 zone; cantilever left and right exposed ; end vertical left and right exposed;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - Truss designed for wind loads in the plane of the truss only. For studs exposed to wind (normal to the face), see Standard Industry Gable End Details as applicable, or consult qualified building designer as per ANSI/TPI 1.
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
 - All plates are 2x4 MT20 unless otherwise indicated.
 - Gable requires continuous bottom chord bearing.
 - Truss to be fully sheathed from one face or securely braced against lateral movement (i.e. diagonal web).
 - Gable studs spaced at 2-0-0 oc.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 47, 25, 37, 38, 39, 41, 42, 43, 44, 45, 46, 35, 34, 33, 31, 30, 29, 28, 27, 26.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3,2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacompnents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932


Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	T03GE	Common Supported Gable	1	1	176046225

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:07 2025 Page 1
ID:Bx12MwYau_NHkbraGCmHloyOvst-IPG7GxgXHARDHCadxKp7W1vos_AH3zzVw2FvpyhiOM

1-0-0 1-0-0 19-2-0 19-2-0 38-4-0 38-4-0 39-4-0 1-0-0

Scale = 1:65.5



LOADING (psf)		SPACING-		CSI.		DEFL.		PLATES		GRIP	
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.14	Vert(LL)	-0.00 25 n/r 120	MT20		244/190	
Snow (Pf/Pg)	11.6/15.0	Lumber DOL	1.15	BC	0.06	Vert(CT)	-0.01 25 n/r 120				
TCDL	10.0	Rep Stress Incr	YES	WB	0.17	Horz(CT)	0.00 26 n/a n/a				
BCLL	0.0 *	Code IRC2018/TPI2014		Matrix-S							
BCDL	10.0										

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 6-0-0 oc purlins, except end verticals.
BOT CHORD	2x4 SP No.2	BOT CHORD	Rigid ceiling directly applied or 6-0-0 oc bracing.
WEBS	2x4 SP No.3	WEBS	1 Row at midpt 13-37
OTHERS	2x4 SP No.3		

REACTIONS. All bearings 38-4-0.
(lb) - Max Horz 48=-160(LC 14)
Max Uplift All uplift 100 lb or less at joint(s) 48, 38, 39, 40, 42, 43, 44, 45, 46, 47, 36, 35, 34, 32, 31, 30, 29, 28, 27
Max Grav All reactions 250 lb or less at joint(s) 48, 26, 37, 38, 39, 40, 42, 43, 44, 45, 46, 47, 36, 35, 34, 32, 31, 30, 29, 28, 27

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 12-13=-106/276, 13-14=-106/276

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=38ft; eave=2ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Corner(3E) -1-0-0 to 2-10-0, Exterior(2N) 2-10-0 to 19-2-0, Corner(3R) 19-2-0 to 23-2-0, Exterior(2N) 23-2-0 to 39-4-0 zone; cantilever left and right exposed ; end vertical left and right exposed;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - Truss designed for wind loads in the plane of the truss only. For studs exposed to wind (normal to the face), see Standard Industry Gable End Details as applicable, or consult qualified building designer as per ANSI/TPI 1.
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
 - All plates are 2x4 MT20 unless otherwise indicated.
 - Gable requires continuous bottom chord bearing.
 - Truss to be fully sheathed from one face or securely braced against lateral movement (i.e. diagonal web).
 - Gable studs spaced at 2-0-0 oc.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 48, 38, 39, 40, 42, 43, 44, 45, 46, 47, 36, 35, 34, 32, 31, 30, 29, 28, 27.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.




September 3,2025

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	T04	Common	8	1	176046226

Riverside Roof Truss, LLC, Danville, Va - 24541, 8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:08 2025 Page 1
ID:Bxl2MwYau_NHkbraGCmHloyOvst-DbqVTHh92TZ4uL9pV1LM2FlxYG5y0Ok7kanoRFyhiOL
1-0-0 6-10-12 13-6-0 19-2-0 24-10-0 31-5-4 38-0-8
1-0-0 6-10-12 6-7-4 5-8-0 5-8-0 6-7-4 6-7-4

Scale = 1:65.6



LOADING (psf)		SPACING-		CSI.		DEFL.		PLATES		GRIP	
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.72	Vert(LL)	-0.75 16 >602 240	MT20	244/190		
Snow (Pf/Pg)	11.6/15.0	Lumber DOL	1.15	BC	0.92	Vert(CT)	-1.28 16 >354 180	MT20HS	187/143		
TCDL	10.0	Rep Stress Incr	YES	WB	0.65	Horz(CT)	0.08 11 n/a n/a				
BCLL	0.0 *	Code IRC2018/TPI2014		Matrix-MS							
BCDL	10.0										
								Weight: 235 lb		FT = 20%	

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 2-2-0 oc purlins, except end verticals.
BOT CHORD	2x4 SP DSS *Except*	BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing. Except:
	15-17: 2x4 SP No.1		6-0-0 oc bracing: 15-17
WEBS	2x4 SP No.3 *Except*		
	2-20: 2x6 SP No.2, 2-19,10-12: 2x4 SP No.2		

REACTIONS. (size) 20=0-3-8, 11=Mechanical
Max Horz 20=162(LC 15)
Max Uplift 20=-69(LC 16), 11=-29(LC 16)
Max Grav 20=1939(LC 28), 11=1876(LC 29)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
TOP CHORD 2-3=-3302/117, 3-5=-3121/108, 5-6=-3120/193, 6-7=-3101/190, 7-9=-3104/112, 9-10=-3228/126, 2-20=-1799/166, 10-11=-1741/112
BOT CHORD 19-20=-102/585, 18-19=-84/3077, 14-18=0/2170, 13-14=0/2170, 12-13=-81/2931, 11-12=-37/292
WEBS 3-18=-305/107, 5-18=-396/162, 17-18=-85/1184, 6-17=-28/1324, 6-15=-27/1292, 13-15=-83/1151, 7-13=-390/160, 9-13=-276/112, 2-19=-4/2537, 10-12=-45/2663

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=38ft; eave=5ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) -1-0-0 to 2-9-10, Interior(1) 2-9-10 to 19-2-0, Exterior(2R) 19-2-0 to 22-11-10, Interior(1) 22-11-10 to 37-10-12 zone; cantilever left and right exposed ; end vertical left and right exposed;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - This truss has been designed for greater of min roof live load of 12.0 psf or 1.00 times flat roof load of 11.6 psf on overhangs non-concurrent with other live loads.
 - All plates are MT20 plates unless otherwise indicated.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
 - Refer to girder(s) for truss to truss connections.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 20, 11.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3,2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate
818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	V01	Valley	1	1	176046227

Riverside Roof Truss, LLC, Danville, Va - 24541, 8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:08 2025 Page 1


ID:Bxl2MwYau_NHkbraGcmHloyOvst-DbqVTHh92TZ4uL9pV1LM2FI3cGHc0Wa7kanoRFyhiOL

23-1-8

11-6-12

11-6-12

11-6-12



LOADING (psf)	SPACING-	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL (roof) 20.0	2-0-0	TC 0.20	Vert(LL)	n/a	-	n/a	MT20	244/190
Snow (Pf/Pg) 11.6/15.0	Plate Grip DOL 1.15	BC 0.17	Vert(CT)	n/a	-	n/a		
TCDL 10.0	Lumber DOL 1.15	WB 0.15	Horz(CT)	0.00	7	n/a		
BCLL 0.0 *	Rep Stress Incr YES	Matrix-S						
BCDL 10.0	Code IRC2018/TPI2014						Weight: 97 lb	FT = 20%

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.2	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins.
BOT CHORD 2x4 SP No.2	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
OTHERS 2x4 SP No.3	

REACTIONS. All bearings 23-0-10.
(lb) - Max Horz 1=-128(LC 14)
Max Uplift All uplift 100 lb or less at joint(s) 11, 13, 9, 8
Max Grav All reactions 250 lb or less at joint(s) 1, 7 except 10=379(LC 27), 11=431(LC 27), 13=363(LC 27), 9=431(LC 28), 8=363(LC 28)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
WEBS 3-11=-263/125, 5-9=-263/125

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) 0-6-8 to 3-6-12, Interior(1) 3-6-12 to 11-6-12, Exterior(2R) 11-6-12 to 14-6-12, Interior(1) 14-6-12 to 22-7-0 zone; cantilever left and right exposed; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - All plates are 2x4 MT20 unless otherwise indicated.
 - Gable requires continuous bottom chord bearing.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 11, 13, 9, 8.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3, 2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.


Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate
818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	V02	Valley	1	1	176046228

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:09 2025 Page 1
ID:Bx12MwYau_NHkbraGcmHloyOvst-hnOtgdhnpnhxWVWk03lsbbSrEJfd_I_OGyEXL_hyhiOK



LOADING (psf)	SPACING-	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL (roof) 20.0	2-0-0	TC 0.20	Vert(LL)	n/a	-	n/a	MT20	244/190
Snow (Pf/Pg) 11.6/15.0	Plate Grip DOL 1.15	BC 0.17	Vert(CT)	n/a	-	n/a		
TCDL 10.0	Lumber DOL 1.15	WB 0.11	Horz(CT)	0.00	7	n/a		
BCLL 0.0 *	Rep Stress Incr YES	Matrix-S						
BCDL 10.0	Code IRC2018/TPI2014						Weight: 82 lb	FT = 20%

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.2	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins.
BOT CHORD 2x4 SP No.2	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
OTHERS 2x4 SP No.3	

REACTIONS. All bearings 20-2-6.
(lb) - Max Horz 1=112(LC 15)
Max Uplift All uplift 100 lb or less at joint(s) 1, 7, 12, 13, 9, 8
Max Grav All reactions 250 lb or less at joint(s) 1, 7 except 10=370(LC 27), 12=428(LC 27), 13=307(LC 27), 9=428(LC 28), 8=307(LC 28)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
WEBS 3-12=-268/127, 5-9=-268/127

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) 0-6-8 to 3-6-8, Interior(1) 3-6-8 to 10-1-10, Exterior(2R) 10-1-10 to 13-1-10, Interior(1) 13-1-10 to 19-8-11 zone; cantilever left and right exposed; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - All plates are 2x4 MT20 unless otherwise indicated.
 - Gable requires continuous bottom chord bearing.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 1, 7, 12, 13, 9, 8.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.




September 3, 2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate
818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	V03	Valley	1	1	176046229

Riverside Roof Truss, LLC, Danville, Va - 24541, 8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:09 2025 Page 1
ID:BxI2MwYau_NHkbraGcmHloyOvst-hnOtgdhnpnhxWVvk03lsbbSrEcfdLI_uGyEXL_hyhiOK



LOADING (psf)	SPACING-	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL (roof) 20.0	2-0-0	TC 0.25	Vert(LL)	n/a	-	n/a	MT20	244/190
Snow (Pf/Pg) 11.6/15.0	Plate Grip DOL 1.15	BC 0.14	Vert(CT)	n/a	-	n/a		
TCDL 10.0	Lumber DOL 1.15	WB 0.08	Horz(CT)	0.00	5	n/a		
BCLL 0.0 *	Rep Stress Incr YES	Matrix-S					Weight: 67 lb	FT = 20%
BCDL 10.0	Code IRC2018/TPI2014							

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.2	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins.
BOT CHORD 2x4 SP No.2	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
OTHERS 2x4 SP No.3	

REACTIONS.	All bearings 17-4-1.
(lb) - Max Horz	1=-95(LC 14)
Max Uplift	All uplift 100 lb or less at joint(s) 9, 6
Max Grav	All reactions 250 lb or less at joint(s) 1, 5, 7 except 9=391(LC 33), 6=391(LC 34)

FORCES.	(lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
WEBS	2-9=-291/134, 4-6=-291/134

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) 0-6-8 to 3-6-8, Interior(1) 3-6-8 to 8-8-7, Exterior(2R) 8-8-7 to 11-8-7, Interior(1) 11-8-7 to 16-10-7 zone; cantilever left and right exposed; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - Gable requires continuous bottom chord bearing.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 9, 6.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3, 2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate


818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	V04	Valley	1	1	176046230

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:10 2025 Page 1

ID:BxI2MwYau_NHkbraGCMHloyOvst-9_yGuziPa5po8fJCcSNq7gNP73_USOQBvHvW8yhiOJ



LOADING (psf)	SPACING-	CSI.	DEFL.	PLATES	GRIP
TCLL (roof) 20.0	2-0-0	TC 0.20	in (loc) l/defl L/d	MT20	244/190
Snow (Pf/Pg) 11.6/15.0	Plate Grip DOL 1.15	BC 0.12	Vert(LL) n/a - n/a 999		
TCDL 10.0	Lumber DOL 1.15	WB 0.06	Vert(CT) n/a - n/a 999		
BCLL 0.0 *	Rep Stress Incr YES	Matrix-S	Horz(CT) 0.00 5 n/a n/a		
BCDL 10.0	Code IRC2018/TPI2014			Weight: 54 lb	FT = 20%

LUMBER-	BRACING-
TOP CHORD 2x4 SP No.2	TOP CHORD Structural wood sheathing directly applied or 6-0-0 oc purlins.
BOT CHORD 2x4 SP No.2	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
OTHERS 2x4 SP No.3	

REACTIONS. All bearings 14-5-13.
(lb) - Max Horz 1=-78(LC 14)
Max Uplift All uplift 100 lb or less at joint(s) 8, 6
Max Grav All reactions 250 lb or less at joint(s) 1, 5 except 7=272(LC 33), 8=321(LC 34), 6=321(LC 34)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) 0-6-8 to 3-3-5, Interior(1) 3-3-5 to 7-3-5, Exterior(2R) 7-3-5 to 10-3-5, Interior(1) 10-3-5 to 14-0-2 zone; cantilever left and right exposed ; end vertical left and right exposed;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - Gable requires continuous bottom chord bearing.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 8, 6.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3,2025

WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.


Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate

818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	V05	Valley	1	1	176046231

Riverside Roof Truss, LLC, Danville, Va - 24541, 8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:10 2025 Page 1
ID:BxI2MwYau_NHkbraGCMHloyOvst-9_yGuziPa5po8fJCcSNq7gNMI3xQURDQBuhvW8yhiOJ
5-10-3 5-10-3 11-8-6 5-10-3



LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.45	n/a	-	n/a	999
Snow (Pf/Pg)	11.6/15.0	Lumber DOL	1.15	BC	0.28	n/a	-	n/a	999
TCDL	10.0	Rep Stress Incr	YES	WB	0.07	0.00	3	n/a	n/a
BCLL	0.0 *	Code IRC2018/TPI2014	Matrix-S						
BCDL	10.0								

LUMBER-	BRACING-
TOP CHORD	2x4 SP No.2
BOT CHORD	2x4 SP No.2
OTHERS	2x4 SP No.3

REACTIONS. (size) 1=11-7-8, 3=11-7-8, 4=11-7-8
Max Horz 1=-62(LC 14)
Max Uplift 1=-26(LC 16), 3=-26(LC 16)
Max Grav 1=201(LC 2), 3=201(LC 2), 4=447(LC 2)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
WEBS 2-4=-291/106

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) 0-6-8 to 3-6-8, Interior(1) 3-6-8 to 5-10-3, Exterior(2R) 5-10-3 to 8-10-3, Interior(1) 8-10-3 to 11-1-14 zone; cantilever left and right exposed ; end vertical left and right exposed;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - Gable requires continuous bottom chord bearing.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 1, 3.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3, 2025


WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.
Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacomponents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate
818 Soundside Road
Edenton, NC 27932

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	V06	Valley	1	1	176046232

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:11 2025 Page 1
ID:BxI2MwYau_NHkbraGcmHloyOvst-dAWe5Jj2LOxelpuOA9u3gtwZ5TJgDvyZQY0S2ayhiOI



LOADING (psf)		SPACING-		CSI.		DEFL.				PLATES	GRIP
TCLL (roof)	20.0	2-0-0		TC	0.31	in	(loc)	l/defl	L/d		
Snow (Pf/Pg)	11.6/15.0	Plate Grip DOL	1.15	BC	0.15	Vert(LL)	n/a	-	n/a	999	MT20
TCDL	10.0	Lumber DOL	1.15	WB	0.04	Vert(CT)	n/a	-	n/a	999	244/190
BCLL	0.0 *	Rep Stress Incr	YES	Matrix-P		Horz(CT)	0.00	3	n/a	n/a	
BCDL	10.0	Code IRC2018/TPI2014									Weight: 29 lb
											FT = 20%

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 6'-0'-0" oc purlins.
BOT CHORD	2x4 SP No.2	BOT CHORD	Rigid ceiling directly applied or 10'-0'-0" oc bracing.
OTHERS	2x4 SP No.3		

REACTIONS.	(size) 1=8-9-3, 3=8-9-3, 4=8-9-3
	Max Horz 1=45(LC 15)
	Max Uplift 1=-26(LC 16), 3=-26(LC 16)
	Max Grav 1=162(LC 2), 3=162(LC 2), 4=296(LC 2)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.


- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) 0-6-8 to 3-6-8, Interior(1) 3-6-8 to 4-5-1, Exterior(2R) 4-5-1 to 7-5-1, Interior(1) 7-5-1 to 8-3-9 zone; cantilever left and right exposed; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - Gable requires continuous bottom chord bearing.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 1, 3.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3, 2025

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	V07	Valley	1	1	176046233

Riverside Roof Truss, LLC,	Danville, Va - 24541,	8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:11 2025 Page 1
		ID:Bxl2MwYau_NHkbraGcmHloyOvst-dAWe5Jj2LOxelpuOA9u3gtwciTL4DvEZQY0S2ayhiOI
		5-11-13
		2-11-14



LOADING (psf)	SPACING-	CSI.	DEFL.	in (loc)	I/defl	L/d	PLATES	GRIP
TCLL (roof) 20.0	2-0-0	TC 0.11	Vert(LL)	n/a	-	n/a	MT20	244/190
Snow (Pf/Pg) 11.6/15.0	Plate Grip DOL 1.15	BC 0.06	Vert(CT)	n/a	-	n/a		
TCDL 10.0	Lumber DOL 1.15	WB 0.03	Horz(CT)	0.00	3	n/a		
BCLL 0.0 *	Rep Stress Incr YES	Matrix-P						
BCDL 10.0	Code IRC2018/TPI2014						Weight: 19 lb	FT = 20%

LUMBER-		BRACING-	
TOP CHORD 2x4 SP No.2		TOP CHORD	Structural wood sheathing directly applied or 5-11-13 oc purlins.
BOT CHORD 2x4 SP No.2		BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing.
OTHERS 2x4 SP No.3			

REACTIONS.	(size) 1=5-10-15, 3=5-10-15, 4=5-10-15
	Max Horz 1=-29(LC 14)
	Max Uplift 1=-17(LC 16), 3=-17(LC 16)
	Max Grav 1=102(LC 2), 3=102(LC 2), 4=187(LC 2)

FORCES.	(lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.
----------------	--

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) zone; cantilever left and right exposed ; end vertical left and right exposed;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15) Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - Gable requires continuous bottom chord bearing.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 1, 3.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3,2025

Job	Truss	Truss Type	Qty	Ply	25-5068-A RVF-LOT 36 ROOF
25-3407-B	V08	Valley	1	1	176046234

Riverside Roof Truss, LLC, Danville, Va - 24541,

8.830 s Aug 14 2025 MiTek Industries, Inc. Tue Sep 2 10:04:12 2025 Page 1
ID:BxI2MwYau_NHkbraGCMHloyOvst-5M40Jfkg6i3VNzTbktPID5ToQthWyMtiFCm0b0yhiOH




Plate Offsets (X,Y)-- [2:0-2:0,Edge]									
LOADING (psf)		SPACING-		CSI.		DEFL.		PLATES	
TCLL (roof)	20.0	Plate Grip DOL	1.15	TC	0.02	Vert(LL)	n/a	MT20	244/190
Snow (Pf/Pg)	11.6/15.0	Lumber DOL	1.15	BC	0.05	Vert(CT)	n/a		
TCDL	10.0	Rep Stress Incr	YES	WB	0.00	Horz(CT)	0.00		
BCLL	0.0 *	Code	IRC2018/TPI2014	Matrix-P					
BCDL	10.0							Weight: 8 lb	FT = 20%

LUMBER-		BRACING-	
TOP CHORD	2x4 SP No.2	TOP CHORD	Structural wood sheathing directly applied or 3-1-8 oc purlins.
BOT CHORD	2x4 SP No.2	BOT CHORD	Rigid ceiling directly applied or 10-0-0 oc bracing.

REACTIONS. (size) 1=3-0-10, 3=3-0-10
Max Horz 1=-12(LC 14)
Max Uplift 1=-5(LC 16), 3=-5(LC 16)
Max Grav 1=82(LC 2), 3=82(LC 2)

FORCES. (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
 - Wind: ASCE 7-16; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; B=45ft; L=24ft; eave=4ft; Cat. II; Exp B; Enclosed; MWFRS (directional) and C-C Exterior(2E) zone; cantilever left and right exposed ; end vertical left and right exposed;C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
 - TCLL: ASCE 7-16; Pr=20.0 psf (roof LL: Lum DOL=1.15 Plate DOL=1.15); Pg=15.0 psf; Pf=11.6 psf (Lum DOL = 1.15 Plate DOL = 1.15); Is=1.0; Rough Cat B; Partially Exp.; Ce=1.0; Cs=1.00; Ct=1.10
 - Unbalanced snow loads have been considered for this design.
 - Gable requires continuous bottom chord bearing.
 - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
 - * This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
 - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) 1, 3.
 - This truss is designed in accordance with the 2018 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.



September 3,2025




WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 1/2/2023 BEFORE USE.

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria and DSB-22** available from Truss Plate Institute (www.tpinst.org) and **BCSI Building Component Safety Information** available from the Structural Building Component Association (www.sbcacompnents.com)

ENGINEERING BY
TRENCO
A MiTek Affiliate
818 Soundside Road
Edenton, NC 27932

Symbols

PLATE LOCATION AND ORIENTATION



* Plate location details available in MITek software or upon request.

PLATE SIZE

4 X 4


The first dimension is the plate width measured perpendicular to slots. Second dimension is the length parallel to slots.

LATERAL BRACING LOCATION



Indicated by symbol shown and/or by text in the bracing section of the output. Use T or I bracing if indicated.


BEARING



Indicates location where bearings (supports) occur. Icons vary but reaction section indicates joint number/letter where bearings occur. Min size shown is for crushing only.

Industry Standards:
ANSI/TP1.1: National Design Specification for Metal Plate Connected Wood Truss Construction.
DSB-22: Design Standard for Bracing.
BCSI: Building Component Safety Information, Guide to Good Practice for Handling, Installing, Restraining & Bracing of Metal Plate Connected Wood Trusses.

Numbering System



JOINTS ARE GENERALLY NUMBERED/LETTERED CLOCKWISE AROUND THE TRUSS STARTING AT THE JOINT FARTHEST TO THE LEFT.

CHORDS AND WEBS ARE IDENTIFIED BY END JOINT NUMBERS/LETTERS.

Product Code Approvals

ICC-ES Reports:
ESR-1988, ESR-2362, ESR-2685, ESR-3282
ESR-4722, ESL-1388

Design General Notes

Trusses are designed for wind loads in the plane of the truss unless otherwise shown.
Lumber design values are in accordance with ANSI/TP1 1 section 6.3. These truss designs rely on lumber values established by others.

© 2023 MITek® All Rights Reserved

General Safety Notes

Failure to Follow Could Cause Property Damage or Personal Injury

1. Additional stability bracing for truss system, e.g. diagonal or X-bracing, is always required. See BCSI.
2. Truss bracing must be designed by an engineer. For wide truss spacing, individual lateral braces themselves may require bracing, or alternative Tor I bracing should be considered.
3. Never exceed the design loading shown and never stack materials on inadequately braced trusses.
4. Provide copies of this truss design to the building designer, erection supervisor, property owner and all other interested parties.
5. Cut members to bear tightly against each other.
6. Place plates on each face of truss at each joint and embed fully. Knots and wane at joint locations are regulated by ANSI/TP1 1.
7. Design assumes trusses will be suitably protected from the environment in accord with ANSI/TP1 1.
8. Unless otherwise noted, moisture content of lumber shall not exceed 19% at time of fabrication.
9. Unless expressly noted, this design is not applicable for use with fire retardant, preservative treated, or green lumber.
10. Camber is a non-structural consideration and is the responsibility of truss fabricator. General practice is to camber for dead load deflection.
11. Plate type, size, orientation and location dimensions indicated are minimum plating requirements.
12. Lumber used shall be of the species and size, and in all respects, equal to or better than that specified.
13. Top chords must be sheathed or purlins provided at spacing indicated on design.
14. Bottom chords require lateral bracing at 10 ft. spacing, or less, if no ceiling is installed, unless otherwise noted.
15. Connections not shown are the responsibility of others.
16. Do not cut or alter truss member or plate without prior approval of an engineer.
17. Install and load vertically unless indicated otherwise.
18. Use of green or treated lumber may pose unacceptable environmental, health or performance risks. Consult with project engineer before use.
19. Review all portions of this design (front, back, words and pictures) before use. Reviewing pictures alone is not sufficient.
20. Design assumes manufacture in accordance with ANSI/TP1 1 Quality Criteria.
21. The design does not take into account any dynamic or other loads other than those expressly stated.

MITek

ENGINEERING BY
TRENCO
A MITek Affiliate

MITek Engineering Reference Sheet: MIL-7473 rev. 1/2/2023