



Reilly Road Industrial Park
Fayetteville, N.C. 28309
Phone: (910) 864-8787
Fax: (910) 864-4444

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature_____

Sales Area

LOAD CHART FOR JACK STUDS


(BASED ON TABLES R502.5(1) & (b))

NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADER/GIRDER				
END REACTION (# OF JOIST) REQ'D STUDS FOR (3/4") HEADER		END REACTION (# OF JOIST) REQ'D STUDS FOR (3/4") HEADER		END REACTION (# OF JOIST) REQ'D STUDS FOR (3/4") HEADER
1700	1	2550	1	3400
3400	2	5100	2	6800
5100	3	7650	3	10200
6800	4	10200	4	13600
8500	5	12750	5	17000
10200	6	15300	6	
11900	7			
13600	8			
15300	9			

COUNTY	Harnett
ADDRESS	78 Alder Dr., Cameron, NC
MODEL	Floor
DATE REV.	9/26/2025
DRAWN BY	Neil Baggett
SALESMAN	Neil Baggett

BUILDER	Precision Custom Homes
JOB NAME	Lot 65 Magnolia Hills
PLAN	Hayek w/10'X15' CP
SEAL DATE	9/23/2025
QUOTE #	N/A
JOB #	251447-B

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.
These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSCI-B1 and BCSCI-B3 provided with the truss delivery package or online at sbindustry.com



Dimension Notes
1. All exterior wall to wall dimensions are to face of stud unless noted otherwise
2. All interior wall dimensions are to face of stud unless noted otherwise
3. All exterior wall to truss dimensions are to face of stud unless noted otherwise

Plumbing Drop Notes
1. Plumbing drop locations shown are NOT exact.
2. Contractor to verify ALL plumbing drop locations prior to setting Floor Trusses.
3. Adjust spacing as needed not to exceed 24"oc.

Roof Area	= 2595.11 sq.ft.
Ridge Line	= 20.42 ft.
Hip Line	= 180.1 ft.
Horiz. OH	= 254.58 ft.
Raked OH	= 22.56 ft.
Decking	= 89 sheets

All Walls Shown Are
Considered Load Bearing

▲ = Indicates Left End of Truss
(Reference Engineered Truss Drawing)
Do Not Erect Trusses Backwards

1 Truss Placement Plan
Scale: 1/4"=1'

Hatch Legend	
	Flush Beam
	Padded HVAC
	2nd Floor Walls @ 8' 1 1/2" UNO
	Drop Beam


Connector Information					Nail Information	
Sym	Product	Manuf	Qty	Supported Member	Header	Truss
	HJC26	USP	7	Varies	16d/3-1/2"	10d/3"

PlotID	Length	Products			Plies	Net Qty	Fab Type
		Product					
DB1	10' 3 1/2"	1-3/4"x 9-1/4" LVL Kerto-S		2	4	FF	
DB2	6' 7"	1-3/4"x 9-1/4" LVL Kerto-S		2	2	FF	
HDR1	6' 7"	1-3/4"x 9-1/4" LVL Kerto-S		2	2	FF	
HDR1	5' 11"	1-3/4"x 9-1/4" LVL Kerto-S		2	2	FF	
GDH	21' 10 1/2"	1-3/4"x 11-7/8" LVL Kerto-S		2	2	FF	
F81	22' 4"	1-3/4"x 23-7/8" LVL Kerto-S		3	3	FF	
DB3	20' 1 1/2"	2x12 SP No.2		2	2	FF	

Products					
PlotID	Length	Product	Plies	Net Qty	Fab Type
HDR3	5' 11"	1-3/4"x 9-1/4" LVL Kerto-S	2	2	FF

All Truss Reactions are Less than 3,000 lbs. Unless Noted Otherwise.

 -- Denotes Reaction Greater than 3,000 lbs.
Reaction / # of Studs



Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature

Sales Area

LOAD CHART FOR JACK STUDS

(BASED ON TABLES P502.5(1) & (b))


NUMBER OF JACK STUDS REQUIRED @ EA END OF
HEADER/GIRDER

END REACTION (UP TO) (2) STUDIES FOR (3) JLY HEADER	END REACTION (UP TO) (2) STUDIES FOR (3) JLY HEADER	END REACTION (UP TO) (2) STUDIES FOR (3) JLY HEADER	END REACTION (UP TO) (2) STUDIES FOR (3) JLY HEADER
1700 1	2550 1	3400	
3400 2	5100 2	6800	
5100 3	7650 3	10200	
6800 4	10200 4	13600	
8500 5	12750 5	17000	
10200 6	15300 6		
11900 7			
13600 8			
15300 9			

COUNTY	Harnett
ADDRESS	78 Alder Dr., Cameron, NC
MODEL	Roof
DATE REV.	9/26/2025
DRAWN BY	Neil Baggett
CALCULATED BY	Neil Baggett

BUILDER	Precision Custom Homes
JOB NAME	Lot 65 Magnolia Hills
PLAN	Hayek w/10'X15' CP
SEAL DATE	9/23/2025
QUOTE #	N/A
JOB #	251447-A

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCBSI-B1 and BCBSI-B3 provided with this delivery package or online at sbindustry.com



Dimension Notes

1. All exterior wall to wall dimensions are to face of stud unless noted otherwise
2. All interior wall dimensions are to face of stud unless noted otherwise
3. All exterior wall to truss dimensions are to face of stud unless noted otherwise

Plumbing Drop Notes

1. Plumbing drop locations shown are NOT exact.
2. Contractor to verify ALL plumbing drop locations prior to setting Floor Trusses.
3. Adjust spacing as needed not to exceed 24"oc.

Roof Area	= 2582.69 sq.ft.
Ridge Line	= 20.42 ft.
Hip Line	= 180.1 ft.
Horiz. OH	= 254.58 ft.
Raked OH	= 21.43 ft.
Decking	= 89 sheets

All Walls Shown Are
Considered Load Bearing

▲ = Indicates Left End of Truss
(Reference Engineered Truss Drawing)
Do Not Erect Trusses Backwards

1 Truss Placement Plan
Scale: 1/4"=1'

Hatch Legend

	Flush Beam
	Padded HVAC
	2nd Floor Walls @ 8' 1 1/2" UNO
	Drop Beam

Connector Information					Nail Information	
Sym	Product	Manuf	Qty	Supported Member	Header	Truss
	HJC26	USP	7	Varies	16d/3-1/2"	10d/3

PlotID	Length	Product	Products		
			Plies	Net Qty	Fab Typ
DB1	10' 3 1/2"	1-3/4" X 9-1/4" LVL Kerto-S	2	4	FF
DB2	6' 7"	1-3/4" X 9-1/4" LVL Kerto-S	2	2	FF
HD2	6' 7"	1-3/4" X 9-1/4" LVL Kerto-S	2	2	FF
HD1	5' 11"	1-3/4" X 9-1/4" LVL Kerto-S	2	2	FF
GDH	21' 10 1/2"	1-3/4" X 11-7/8" LVL Kerto-S	2	2	FF
FB1	22' 4"	1-3/4" X 23-7/8" LVL Kerto-S	3	3	FF
DB3	20' 1 1/2"	2x12 SP No.2	2	2	FF

Products					
PlotID	Length	Product	Plies	Net Qty	Fab Type
HDR3	5' 11"	1-3/4"x 9-1/4" LVL Kerto-S	2	2	FF

All Truss Reactions are Less than 3,000 lbs. Unless Noted Otherwise.

○ -- Denotes Reaction Greater than 3,000 lbs.
Reaction / # of Studs