

HARNETT COUNTY ENVIROMENTAL HEALTH

NORTH CAROLINA	File/Permit #: SFD2510-0003
IMPROVEMENT PERMIT (
New Expansion Repair System F Owner: SIGNATURE HOME BUILDERS INC Applicant:	Relocation
	ntifier: 0682-26-8974.000
	Block: Section:
Facility Type: SFD 40' x 58' Number of bedrooms: 4 Number of Occu	
Design Daily Flow: 480 GPD LTAR (Initial): .35 gpd/ft ² LTA	AR (Repair): .35 gpd/ft²
Wastewater System Type: 25% Reduction System	
Pump Required: Yes No May be required Usable Depth to Limiti	
Wastewater System Type 50% Reduction System (F	S = N = N = N
Pump Required: Yes No May be required Usable Depth to Limiti	ng Condition (Repair): 40"
Effluent Standard: 🔳 DSE 🔲 HSE 🔲 Other: Type of Water Supply: 🔲 P	rivate well Municipal Supply Other:
Permit conditions:	
No Foundation or Gutter Drains to be Directed Towards Septic System. No Cutting or Grading of Soil in Septic or Septic Repair Area.	
The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for requirements. <u>This permit is subject to revocation if the site plan, plat, or the intended use changes.</u> The Improvements is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.	
Authorized Agent's Printed Name: Ren Levocz	Date: 10/27/2025
Authorized Agent's Printed Name: Ren Levocz Authorized Agent's Signature: Ren Levocz	Expiration Date: 10/27/2030
CONSTRUCTION AUTHORIZAT	ION (CA)
	Relocation Change of Use
Owner: SIGNATURE HOME BUILDERS INC Applicant: S	SIGNATURE HOME BUILDERS INC
Property Location: 127 CROATOKE CT ANGIER, NC 27501 PIN/Lot Ide	entifier: 0682-26-8974.000
Subdivision: MABRY RIDGE Lot #: 5	Block: Section:
Subdivision: MABRY RIDGE Lot #: 5 Facility Type: SFD 40' x 58' Number of bedrooms: 4 Number of Occur	upants: Other:
Design Daily Flow: 480 GPD LTAR: .35 gpd/ft ²	
Effluent Standard: DSE HSE Other: Type of Water Supply: P	rivate well Municipal Supply Other:
Installation Requirements/Conditions	
Wastewater System Type: 25% Reduction System	Pump Required: Yes No May be required
Septic Tank Size: 1,000 gallons Total Trench Length: 370' feet Tre	ench Spacing: 9 feet on center
Pump Tank Size: gallons Maximum Trench Depth: 18"-28" inches Soi Trench Width: 36" inches Distribution Method: ■ Serial D-Box or Pa	
	arallel Pressure Manifold Other:
Artificial Drainage Required: Yes No If yes, please specify details:	
Permit conditions: No Foundation or Gutter Drains to be Directed Towards Septic System. No Cutting or Grading of Soil in Septic or Septic Repair Area.	
The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Experiment of 15A NCAC 18E, or 15A NCAC 18E,	tion Authorization shall not be affected by a change in ownership of NC 18A .1900, as applicable, and to the conditions of this permit.
Authorized Agent's Printed Name: Ren Levocz	Date: 10/27/25
Authorized Agent's Signature:	Expiration Date: 10/27/2030

*See attached site sketch

Date: ___

Owner/Legal Representative Signature: _____

SITE SKETCH

 $_{PIN}$ 0682-26-8974.000

Permit Number SFD2510-0003

SIGNATURE HOME BUILDERS INC	MABRY RIDGE Lot 5	
Applicant's Name	Subdivision/Section/Lot Number	
Ren Levocz	10/27/2025	
Authorized State Agent	Date	

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

