

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

Oct 16th, 2025

Signature Home Builders LLC
1209 N Main St
Lillington, NC 27546

Re: Status of Permit Application-SFD2510-0005 SFD2509-0092-Lot 6 & 7

To whom it may concern,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

☐ 1. Survey Corner Irons need to be uncovered and clearly demonstrated. (25.00 Fee Incurred)

☐ 2. House Box needs to be marked/demonstrated clearly. (25.00 Fee Incurred)

☐ 3. Directions not clear to property (\$25.00 fee incurred)

☐ 4. Needs more clearing. Do not disturb the soil.

☐ 5. Driveway not shown on site plan

☐ 6. Backhoe Pits Required

☒ 7. Other- Based on the Soils Found and Limited Available Space it will only accommodate T&J panel block System with no room for error. To increase the success of the system the following will be required.

Will Need House Location Moved to the Far back of the lot with driveway hugging the right side of the property as if you were standing on Croatoke ct. Will need to update the site plan and remark the changes onsite to match the new house box.

Your application will be put on hold until the selected items above have been addressed.
Please call 910-893-7525 to schedule your property for evaluation.

Sincerely,



Reynold Levocz R.E.H.S.
Environmental Health Specialist
RL/kh
Copy: Central Permitting