



NC DEPARTMENT OF
**HEALTH AND
HUMAN SERVICES**

ROY COOPER • Governor

KODY H. KINSLEY • Secretary

MARK BENTON • Chief Deputy Secretary for Health

SUSAN KANSAGRA • Assistant Secretary for Public Health

Division of Public Health

Submittal Includes: (a2) Improvement Permit (a2) Construction Authorization Fee \$ _____

IMPROVEMENT PERMIT FOR G.S. 130A-335(a2)

County: Harnett

PIN/Lot Identifier: 9588-74-0969.000

Issued To: Smith Douglas Homes

Property Location: 110 PINE VISTA WAY SANFORD NC 27332

Subdivision (if applicable) BRIARWOOD BLUFF Lot #: LOT 25 Block: _____ Section: _____

LSS Report Provided: Yes No

If yes, name and license number of LSS: Stephen W Bristow # 1167

New

Expansion

System Relocation

Change of Use

Facility Type: SFD

Number of bedrooms: 3 Number of Occupants: 6 Other: _____

Design Wastewater Strength: Domestic High Strength Industrial Process Wastewater

Proposed Design Daily Flow: 360 GPD Proposed LTAR (Initial): .45 Proposed LTAR (Repair): .45

Proposed Wastewater System Type*: IIIb (Initial) Pump Required: Yes No May be required

Proposed Wastewater System Type*: IIIb (Repair) Pump Required: Yes No May be required

*Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII

Effluent Standard: DSE HSE NSF/ANSI 40 TS-I TS-II RCW

Saprolite System (Initial): Yes No Saprolite System (Repair): Yes No

Fill System (Initial): Yes No If yes, specify: New Existing (when adding more than 6 inches of fill to system area provide a fill plan)

Fill System (Repair): Yes No If yes, specify: New Existing (when adding more than 6 inches of fill to system area provide a fill plan)

Usable Depth to LC (Initial): 48 Usable Depth to LC (Repair): 48 *Limiting Condition

Max. Trench Depth (Initial): 35 Max. Trench Depth (Repair): 35 *Measured on the downhill side of the trench

Artificial Drainage Required: Yes No If yes, please specify details: _____

Type of Water Supply: Private well Public well Shared well Municipal Supply Spring Other: _____

Drainfield location meets requirements of Rule .0508: Yes No Drainfield location meets requirements of Rule .0601: Yes No

Permit valid for: Five years [site plan submitted pursuant to GS 130A-334(13a)] No expiration [plat submitted pursuant to GS 130A-334(7a)]

Permit conditions:

Permit conditions: Use EZ Flow Product for this septic drain field installation in this sandy soil. Do not use chambers or this permit is void.

Any NC State approved ST or PT is considered adequate for this septic installation Call if you have questions 919-906-4737

Licensed Soil Scientist Print Name: Steve Bristow #1167

Licensed Soil Scientist Signature: Steve Bristow Date: 10/15/25

The LSS evaluation is being submitted pursuant to and meets the requirements of G.S. 130A-335(a2).

See attached site sketch



This Section for Local Health Department Use Only

Initial submittal received: 10/23/25 by OT
Date Initials

G.S. 130A-335(a3) states the following:

When an applicant for an Improvement Permit submits to a local health department an Improvement Permit application, the permit fee charged by the local health department, the common form developed by the Department, and a soil evaluation pursuant to subsection (a2) of this section, the local health department shall, within five business days of receiving the application, conduct a completeness review of the submittal. A determination of completeness means that the Improvement Permit includes all of the required components. If the local health department determines that the Improvement Permit is incomplete, the local health department shall notify the applicant of the components needed to complete the Improvement Permit. The applicant may submit additional information to the local health department to cure the deficiencies in the Improvement Permit. The local health department shall make a final determination as to whether the Improvement Permit is complete within five business days after the local health department receives the additional information from the applicant. If the local health department fails to act within any period set out in this subsection, the applicant may treat the failure to act as a determination of completeness. The Department shall develop a common form for use as the Improvement Permit.

The review for completeness of this Improvement Permit was conducted in accordance with G.S. 130A-335(a3). This Improvement Permit is determined to be:

Incomplete (If box is checked, information in this section is required.)

The following items are missing:

Copies of this were sent to the LSS and the Applicant on _____
Date _____

State Authorized Agent: _____ Date: _____

Complete

State Authorized Agent: _____ Date: 10/29/25

This Improvement Permit is issued pursuant to G.S. 130A-335 (a2) and (a3) using the signed and sealed LSS/LG evaluation(s) attached here. The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

The Department, the Department's authorized agents, and the local health departments shall be discharged and released from any liabilities, duties, and responsibilities imposed by statute or in common law from any claim arising out of or attributed to evaluations, submittals, or actions from a licensed soil scientist or licensed geologist pursuant to GS 130A-335(a2).

Improvement Permit Expiration Date: 10/29/30

See attached site sketch

CONSTRUCTION AUTHORIZATION FOR G.S. 130A-335(a2)

County: Harnett

Pre-Construction Conference Required: Yes No

PIN/Lot Identifier: 9588-74-0969.000

Issued To: Smith Douglas Homes

Property Location: 110 PINE VISTA WAY SANFORD NC 27332

AOWE/PE Plans/Evaluations Provided: Yes No If yes, name and license number of AOWE/PE: Steve Bristow # 10012E

Facility Type: SFD

Number of bedrooms: 3 Number of Occupants: 6 Other: _____

New Expansion Repair System Relocation Change of Use

Basement? Yes No Basement Fixtures? Yes No

Crawl Space? Yes No Slab Foundation? Yes No

Type of Wastewater System* IIIb (Initial) IIIb (Repair)

*Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII

Design Daily Flow: 360 GPD Wastewater Strength: Domestic High Strength Industrial Process WW

Session Law 2014-120 Section 53, Engineering Design Utilizing Low-flow Fixtures and Low-flow Technologies? Yes No
(if yes, please provide engineering documentation)

Effluent Standard: DSE HSE NSF/ANSI 40 TS-I TS-II RCW

Type of Water Supply: Private well Public well Shared well Municipal Supply Spring Other: _____

Installation Requirements/Conditions

Septic Tank Size: 1000 gallons Total Trench/Bed Length: 315 feet Trench/Bed Spacing: 9 feet on center

Trench/Bed Width: 36 inches LTAR: .45 gpd/ft² Usable Depth to LC (Initial): 48 ^xLimiting condition

Soil Cover: 6 inches Slope Corrected Maximum Trench/Bed Depth[†]: 35 inches ^{* Measured on the downhill side of the trench}

Pump Tank Size (if applicable): 1000 gallons Requires more than 1 pump? Yes No

Pump Requirements: 16.95 ft. TDH vs. 27.40 GPM Grease Trap Size (if applicable): _____ gallons

Distribution Method: Serial D-Box or Parallel Pressure Manifold(s) LPP Other: _____

Artificial Drainage Required: Yes No If yes, please specify details: _____

Legal Agreements (If the answer is "Yes" to any type of legal agreements, please attach a copy of the agreement.)

Multi-party Agreement Required [.0204(g)]: Yes No Declaration of Restrictive Covenants: Yes No

Easement, Right-of-Way, or Encroachment Agreement Required [.0301(b)]: Yes No

Management Entity Required: Yes No Minimum O&M Requirements: _____

Permit conditions:

Permit conditions: Use EZ Flow Product for this septic drain field installation in this sandy soil. Do not use chambers or this permit is void.

Any NC State approved ST or PT is considered adequate for this septic installation Call if you have questions 919-906-4737

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

AOWE/PE Print Name: Steve Bristow 10012E

AOWE/PE Signature: Steve Bristow

Date: 10/15/25

This AOWE/PE submittal is pursuant to and meets the requirements of G.S. 130A-335(a2) and (a5).

See attached site sketch



This Section for Local Health Department Use Only

Initial submittal received: 10/23/25 by OT
Date Initials

G.S. 130A-335(a5) states the following:

When an applicant for a Construction Authorization, or an Improvement Permit and Construction Authorization together, submits a Construction Authorization, or an Improvement Permit and Construction Authorization application together, the permit fee charged by the local health department, the common form developed by the Department, and any necessary signed and sealed plans or evaluations conducted by a person licensed pursuant to Chapter 89C of the General Statutes as a licensed engineer or a person certified pursuant to Article 5 of Chapter 90A of the General Statutes as an Authorized On-Site Wastewater Evaluator, the local health department shall, within five business days of receiving the application, conduct a completeness review of the submittal. A determination of completeness means that the Construction Authorization or Improvement Permit and Construction Authorization includes all of the required components. If the local health department determines that the Construction Authorization or Improvement Permit and Construction Authorization is incomplete, the local health department shall notify the applicant of the components needed to complete the Construction Authorization or Improvement Permit and Construction Authorization. The applicant may submit additional information to the local health department to cure the deficiencies in the Construction Authorization or Improvement Permit and Construction Authorization. The local health department shall make a final determination as to whether the Construction Authorization or Improvement Permit and Construction Authorization is complete within five business days after the local health department receives the additional information from the applicant. If the local health department fails to act within any period set out in this subsection, the applicant may treat the failure to act as a determination of completeness. The applicant may apply for the building permit for the project upon the decision of completeness of the Construction Authorization or Improvement Permit and Construction Authorization by the local health department or if the local health department fails to act within five business days. The Authorized On-Site Wastewater Evaluator or licensed engineer submitting the evaluation pursuant to this subsection may request that the local health department revoke or suspend the Construction Authorization or Improvement Permit and Construction Authorization for cause. Upon written request of the Authorized On-Site Wastewater Evaluator or licensed engineer, the local health department shall suspend or revoke the Construction Authorization or Improvement Permit and Construction Authorization pursuant to G.S. 130A-23. The Department shall develop a common form for use as the Construction Authorization.

The review for completeness of this Construction Authorization was conducted in accordance with G.S. 130A-335(a5). This

Construction Authorization is determined to be:

Incomplete (If box is checked, information in this section is required.)

The following items are missing: _____

Copies of this were sent to the AOWE/PE and the Applicant on _____
Date _____

State Authorized Agent: _____ Date: _____

Complete

State Authorized Agent: _____ Date of Issuance: 10/25/25

This Construction Authorization is issued pursuant to G.S. 130A-335(a2) and (a5) using the signed and sealed plans or evaluations attached here. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

The Department, the Department's authorized agents, and the local health departments shall be discharged and released from any liabilities, duties, and responsibilities imposed by statute or in common law from any claim arising out of or attributed to plans, evaluations, preconstruction conference findings, submittals, or actions from a person licensed pursuant to Chapter 89C of the General Statutes as a licensed engineer or a person certified pursuant to Article 5 of Chapter 90A of the General Statutes as an Authorized On-Site Wastewater Evaluator in GS 130A-335(a2), (a5), and (a7). The Department, the Department's authorized agents, and the local health departments shall be responsible and bear liability for their actions and evaluations and other obligations under State law or rule, including the issuance of the operations permit pursuant to GS 130A-337.

Construction Authorization Expiration Date: 10/29/30

See attached site sketch

Briarwood Bluff Lot 25 System Detail

LOT INFORMATION:

PIN: 9588-74-0969.000
REFERENCE: DB. 4291, PG. 2161
TOTAL LOT AREA = 0.662 AC = 28,815 SF
 HOUSE = 1,134 SF
 PORCH = 62 SF
 SIDEWALK/STEPS = 36 SF
 DRIVEWAY (TO P/L) = 607 SF
 PATIO = 120 SF
PROPOSED IMPERVIOUS = 1,959 SF
PERCENT IMPERVIOUS = 6.80%

BUILDING SETBACKS
FRONT - 35'
SIDE - 10'
REAR - 25'
STREET SIDE - 20'

Elevation Table

Benchmark = 100'
Line 1 = 102.3'
Line 2 = 102.3'
Line 3 = 102.5'
Line 4 = 102.5'
Line 5 = 102.5'
Line 6 = 102.5'
Line 7 = 102.9'
Line 8 = 102.5'
Line 9 = 102.1'




System Details

Initial:
1000 gal Septic Tank
1000 gal Pump Tank
0.45 LTAR
Lines 1-5 (315')
Accepted - Manifold
Distribution - Parallel
Product - EZ Flow
35" MTD

Repair:
1000 gal Septic Tank
1000 gal Pump Tank
0.45 LTAR
Lines 6-9 (275')
Accepted - Manifold
Distribution - Parallel
Product - EZ Flow
35" MTD

IMPROVED OPEN SPACE

OPEN SPACE 3



Legend

Initial Repair



Briarwood Bluff Lot 25 System Detail

LOT INFORMATION:

PIN: 9588-74-0969.000
REFERENCE: DB. 4291, PG. 2161
TOTAL LOT AREA = 0.662 AC = 28,815 SF
 HOUSE = 1,134 SF
 PORCH = 62 SF
 SIDEWALK/STEPS = 36 SF
 DRIVEWAY (TO P/L) = 607 SF
 PATIO = 120 SF
PROPOSED IMPERVIOUS = 1,959 SF
PERCENT IMPERVIOUS = 6.80%

BUILDING SETBACKS
FRONT - 35'
SIDE - 10'
REAR - 25'
STREET SIDE - 20'

PL 2024, PC 336



Elevation Table	
Benchmark	= 100
Line 1	= 102.3'
Line 2	= 102.3'
Line 3	= 102.5'
Line 4	= 102.5'
Line 5	= 102.5'
Line 6	= 102.5'
Line 7	= 102.9'
Line 8	= 102.5'
Line 9	= 102.1'

OULD P
TH ANY
IGHTS-
LOCK.
URISDI
/ THIS P
INDEP
ESTRICT
AN ACC
S HOME
WAY

System Details

Initial:
1000 gal Septic Tank
1000 gal Pump Tank
0.45 LTAR
Lines 1-5 (315')
Accepted - Manifold
Distribution - Parallel
Product - EZ Flow
35' MTD

Repair:
1000 gal Septic Tank
1000 gal Pump Tank
0.45 LTAR
Lines 6-9 (275')
Accepted - Manifold
Distribution - Parallel
Product - EZ Flow
35' MTD



Legend

Initial Repair

