



Planning Services Sign Permit Review Form

PO Box 65
108 E. Front Street
Lillington, NC 27546
Ph: (910) 893- 7525 opt. 4
Fax: (910) 814-6459

Date of Submittal	Application Number	Applicant	Landowner
11/22/2023	SIGN-044477	Coastal Signs and Graphics	Overhills Community Baptist Church

Contact Person	None listed in land use application	Contact Number	843-899-7446
Sign Location		PIN Number	0535-52-2731.000

Proposed Sign			
Type	Dimensions	Location / Setbacks	Illumination
<input type="checkbox"/> Wall <input checked="" type="checkbox"/> Ground <input type="checkbox"/> Monument <input type="checkbox"/> Directory <input type="checkbox"/> Outdoor Advertising	Length Width 8' Height 5' Total Sq. Ft. 40 sq. feet	Not provided. Site plan submitted does not show proposed location of sign.	<input type="checkbox"/> None <input type="checkbox"/> External <input type="checkbox"/> Internal <input checked="" type="checkbox"/> Electronic Message
Total Length of Wall	NA	Total Size of Project / Parcel	<input type="checkbox"/> Less Than 1 Acre <input checked="" type="checkbox"/> Greater Than 1 Acre
Total Sq. Ft. Electronic Message Display	Not provided	Pole Style Ground Sign Encasement	Material Width

Current Signage			
Current Wall Signs	Current Ground Signs	Distance Between Signs On Property	Distance Between Outdoor Advertising Signs
0	Unknown	Unknown	NA

Reviewed By:	Date of Review	Review Results
Sarah Arbour	12/5/2023	<input type="checkbox"/> Approved <input checked="" type="checkbox"/> Denied

Comments	<p>More information is needed to begin the sign review.</p> <p>1. Please submit a site plan which shows the location of the sign. Please include the distance between the proposed sign and the ROW, side property line, and any other sign located on the property (if applicable).</p> <p>2. Please update the sign rendering with the dimensions of the LED portion of the sign. The maximum permitted square footage of this area is 14 square feet.</p> <p>LED Message Boards are subject to the following regulations. This is provided for informational purposes only.</p> <p>Where illuminated signs are permitted, they shall conform to the following requirements: A. All signs illuminated under the provisions of this section shall be constructed to meet the requirements of the National Electric Code.</p>
----------	--

Planning Services

Sign Permit Review Form

B. Display lighting of signs shall be shielded so as to prevent the direction of such light into any area or structure used primarily for residential purposes, residential zoning district, and/or vehicles approaching on a public right-of-way from any direction. No intermittent lighting effects shall be permitted on signs.

C. Signs which contain, include, or are lighted by any flashing, intermittent, or moving lights are prohibited, except as follows: 1. Illuminated signs shall be permitted to provide information such as time, temperature, date, and public announcements related to the business on-site only. 2. Such signs shall be permitted only as part of an otherwise permitted sign or in conjunction with a permitted replacement of an existing sign, provided that the illuminated portion shall be at least 15 percent (15%) of the total square footage area of the sign and shall not exceed 35 percent (35%) of the total square footage area of the sign. 3. Messages on such signs shall not change more than seven (7) times per minute. In no case shall an animated presentation or animated change of frame be allowed. 4. Illuminated signs, as an addition to an existing sign, shall be comparable in composition, durability, and workmanship to the existing sign.

D. Illuminated signs shall be limited to those lighted internally with glass or plastic faces bearing the advertisement; provided, however, that exposed neon tubing and exposed incandescent or other bulbs not exceeding 15 watts each shall be permitted.

