



Planning Services Sign Permit Review Form

PO Box 65
108 E. Front Street
Lillington, NC 27546
Ph: (910) 893- 7525 opt. 4
Fax: (910) 814-6459

Date of Submittal	Application Number	Applicant	Landowner
11/22/2023	SIGN-044477	Coastal Signs and Graphics	Overhills Community Baptist Church

Contact Person	None listed in land use application	Contact Number	843-899-7446
Sign Location		PIN Number	0535-52-2731.000

Proposed Sign			
Type	Dimensions	Location / Setbacks	Illumination
<input type="checkbox"/> Wall <input checked="" type="checkbox"/> Ground <input type="checkbox"/> Monument <input type="checkbox"/> Directory <input type="checkbox"/> Outdoor Advertising	Width 96" (8') Height 118"(9'10") Total Sq. Ft. 6'4 1/8" x 8' = 50.75 sq ft.	15' from ROW Overhills Rd.	<input type="checkbox"/> None <input type="checkbox"/> External <input type="checkbox"/> Internal <input checked="" type="checkbox"/> Electronic Message
Total Length of Wall	NA	Total Size of Project / Parcel	<input type="checkbox"/> Less Than 1 Acre <input checked="" type="checkbox"/> Greater Than 1 Acre
Total Sq. Ft. Electronic Message Display	15.55 sq. feet	Pole Style Ground Sign Encasement	Material Ornamental Metal Width 2'8"

Current Signage			
Current Wall Signs	Current Ground Signs	Distance Between Signs On Property	Distance Between Outdoor Advertising Signs
0	To be removed	NA	NA

Reviewed By:	Date of Review	Review Results
Sarah Arbour	12/5/2023 2 nd Review Site Plan Submitted - 1/4/2024	<input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied

Comments	<p>1. Old sign must be removed.</p> <p>Where illuminated signs are permitted, they shall conform to the following requirements:</p> <p>A. All signs illuminated under the provisions of this section shall be constructed to meet the requirements of the National Electric Code.</p> <p>B. Display lighting of signs shall be shielded so as to prevent the direction of such light into any area or structure used primarily for residential purposes, residential zoning district, and/or vehicles approaching on a public right-of-way from any direction. No intermittent lighting effects shall be permitted on signs.</p> <p>C. Signs which contain, include, or are lighted by any flashing, intermittent, or moving lights are prohibited, except as follows: 1. Illuminated signs shall be permitted to provide information such as time, temperature, date, and public announcements related to the</p>
----------	--

Planning Services

Sign Permit Review Form

business on-site only. 2. Such signs shall be permitted only as part of an otherwise permitted sign or in conjunction with a permitted replacement of an existing sign, provided that the illuminated portion shall be at least 15 percent (15%) of the total square footage area of the sign and shall not exceed 35 percent (35%) of the total square footage area of the sign. 3. Messages on such signs shall not change more than seven (7) times per minute. In no case shall an animated presentation or animated change of frame be allowed. 4. Illuminated signs, as an addition to an existing sign, shall be comparable in composition, durability, and workmanship to the existing sign.


D. Illuminated signs shall be limited to those lighted internally with glass or plastic faces bearing the advertisement; provided, however, that exposed neon tubing and exposed incandescent or other bulbs not exceeding 15 watts each shall be permitted.



1014517-1-s Photo real header
Dimensions: 24.5" x 91.5"
With bleed: 25" x 92"



Planning Services
Sign Permit Review Form



153'' 3.57

Parking lot

