

GENERAL NOTES

INSTALLER TO PROVIDE COMPLETION PHOTOS OF FOUNDATION, CONDUIT (BEFORE & AFTER POUR), GROUT INSTALLATION, MATCH PLATE/SIGN CONNECTIONS, ANY WELDED CONNECTIONS, ELECTRICAL WIRING AND OVERALL ELEVATION.

THIS SIGN IS INTENDED TO BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF ARTICLE 600 OF THE NATIONAL ELECTRIC CODE AND/OR OTHER APPLICABLE LOCAL CODES. THIS INCLUDES PROPER GROUNDING AND BONDING OF THE SIGN.

INSTALLER TO BE SURE SIGNS ARE PROPERLY INSTALLED, CONNECTED AND GROUNDED.

LANDSCAPING MATERIALS SHOULD BE KEPT MINIMUM TWO INCHES AWAY FROM SIGN POLES OR BASE PLATES.

THIS DRAWING IS FOR INSTALLATION PURPOSES ONLY AND NOT TO BE USED FOR MANUFACTURING.

CONCRETE SPECIFICATION

1.70 CU. YDS. TOTAL. CONCRETE SHALL HAVE A MIN. COMPRESSIVE STRENGTH OF 3,000 PSI @ 28 DAYS. REINFORCING STEEL SHALL HAVE A MIN. YIELD STRENGTH OF 60,000 PSI. RECOMMENDED MIN. CURE TIME OF 7 DAYS BEFORE PROCEEDING WITH INSTALLATION.

LIFTING HOLE NOTE

ANY LIFTING HOLES CREATED ARE THE RESPONSIBILITY OF THE INSTALLER. LIFTING HOLES ARE TO BE SEALED BY A CAP PLATE, WELDED OVER TO COVER AND THEN PAINTED.

WELDING NOTE

ANY REQUIRED WELDING IS TO BE COMPLETED BY AN AWS CERTIFIED WELDER QUALIFIED IN THE APPLICABLE POSITIONS NEEDED.

DESIGN NOTE

SIGN, POLE, AND CONCRETE FOUNDATION ARE DESIGNED TO WITHSTAND A WIND LOAD OF 24 PSF.

CONCRETE BASE DESIGNED USING A LATERAL SOIL BEARING CAPACITY OF 150 PSF / FT. OF DEPTH. IF THESE SOIL CONDITIONS DO NOT EXIST AT THE FOUNDATION LOCATION, IT IS THE ERECTOR'S RESPONSIBILITY TO NOTIFY EVERBRITE, LLC PRIOR TO PERFORMING ADDITIONAL EXCAVATION OR ANY CONCRETE PLACEMENT.

INSTALLATION INSTRUCTIONS

1. STAKE FOUNDATION AREA AND CONFIRM FINAL GRADE REQUIREMENTS WITH G. C.
2. EXCAVATE FOUNDATION AREA.
3. SET POLE(S) AND CONDUIT STUB. (PRIMARY ELECTRICAL SERVICE TO BASE BY G. C.)
4. POUR CONCRETE. ALLOW CONCRETE CURE TIME AS REQUIRED. RECOMMENDED MIN. CURE TIME OF 7 DAYS BEFORE PROCEEDING WITH INSTALLATION.
5. MOUNT SIGNAGE ON POLE(S) (INSTALLER TO PROVIDE WIRE BETWEEN SIGN AND BASE OF POLE.)
6. MAKE FINAL ELECTRICAL HOOK UP TO PRIMARY (ALL ELECTRICAL TO MEET LOCAL CODES.)
7. TEST SIGNAGE FOR PROPER FUNCTION AND LIGHTING.
8. REMOVE ANY LIFTING BRACKETS AND REINSTALL BOLTS.
9. CLEAN UP AREA AND REMOVE ANY PACKING MATERIAL. DO NOT DISCARD ANY MATERIAL OR DEBRIS INTO ON SITE DUMPSTERS.

EVERBRITE TO FURNISH

1. 5' X 10' (P50) DG SIGN
2. MOUNTING POLE
3. CLADDING
4. ALL MOUNTING HARDWARE

INSTALLER TO FURNISH

1. ALL ELECTRICAL COMPONENTS REQ'D
2. FOUNDATION

GENERAL CONTRACTOR TO FURNISH PRIMARY WIRES FROM BUILDING TO SIGN


ELECTRICAL SPECIFICATION :

LAMPS : (10) F60T12 CW/HO
 BALLAST : (2) EESB-832-16L
 CURRENT DRAW : 4.8 AMPS @ 120 VOLTS
 60 HZ , (1) 20 AMP CIRCUIT

LUMENS : 54,000 TOTAL
 LUMENS PER SQ FT : 1174
 AREA : 50.94 SQ FT

POLE SPECIFICATIONS

POLE WEIGHT: 682 LBS
 BURIED POLE LENGTH: 6'-0"
 EXPOSED POLE LENGTH: 9'-10 3/8"
 TOTAL POLE LENGTH: 15'-10 3/8"

				INSTALLATION DRAWING		SITE DG20312 72 SPRING HILL CHURCH ROAD LILLINGTON, NC 27546											
				DRAWN BY IMPACT-MCM	DATE 05/31/19												
				CHK BY CJB	DATE 05/31/19	SCALE AS SHOWN	REF										
<table border="1"> <tr> <th>REV</th> <th>DATE</th> <th>BY</th> <th>CHK</th> <th>DESCRIPTION</th> </tr> <tr> <td>A</td> <td>05/31/19</td> <td>IMPACT-MCM</td> <td>CJB</td> <td>RELEASED FOR INSTALLATION</td> </tr> </table>				REV	DATE	BY	CHK	DESCRIPTION	A	05/31/19	IMPACT-MCM	CJB	RELEASED FOR INSTALLATION	PROJECT NO. 407237		DWG NO. IN407237B	REV. A
REV	DATE	BY	CHK	DESCRIPTION													
A	05/31/19	IMPACT-MCM	CJB	RELEASED FOR INSTALLATION													
 <p>Everbrite 4949 SO. 110TH ST. P.O. BOX 20020 GREENFIELD, WI 53220 414-529-3500</p>				<p>THESE DRAWINGS ARE THE EXCLUSIVE PROPERTY OF EVERBRITE, LLC. USE OF, OR DUPLICATION IN ANY MANNER WITHOUT EXPRESS WRITTEN PERMISSION OF EVERBRITE, LLC. IS PROHIBITED.</p>				<p>DOLLAR GENERAL 5' X 10' (P50) SIGN @ 15'-0" OAH</p>									