

**From:** Sarah Arbour  
**Sent:** Thursday, March 19, 2020 10:25 AM  
**To:** 'reception@bcsignage.com'  
**Cc:** Randy L. Baker  
**Subject:** SIGN2003-0001, Sign Permit Review for 35 Plantation Dr., Cameron, Harnett County  
**Attachments:** Sign Review Form Coldwell Banker.docx

Good Morning Janet,

Please find the attached sign review for 35 Plantation Drive in Cameron. More information is needed to move forward in the permitting process.

1. Please submit the total linear feet of the mounting wall. The maximum amount of signage permitted is calculated by the linear feet of the mounting wall.
2. Please submit images of the north and east elevations of the building, and an image of the entire west elevation. If there is an existing sign on the west elevation, dimensions for this sign will be required. A maximum of 2 wall signs are permitted at this location.
3. FYI Only : the sign square footage will be calculated by drawing the smallest parallelogram around the proposed sign, so 34" by 120", or 33.96 square feet.

Please contact me at (910) 814-6414 with any questions. I am here to help.  
A response to comments can be submitted as an attachment to this e-mail.

Kind Regards,

**Sarah Arbour**

Planner I, Harnett County Development Services  
108 E. Front Street Lillington, NC 27546 Ph. # (910) 814-6414