



Planning Services Sign Permit Review Form

PO Box 65
108 E. Front Street
Lillington, NC 27546
Ph: (910) 893- 7525 opt. 4
Fax: (910) 814-6459

| Date of Submittal | Application Number | Applicant | Landowner |
|--|--------------------|-------------------------|-----------------------------------|
| 7/28/2022 2 nd review 8/22/2022 | SIGN2207-0006 | Advance Signs & Service | Macedonia Baptist Church Trustees |

| Contact Person | Contact Number | Sign Location | PIN Number |
|----------------|----------------|--|------------------|
| Debbie Landell | 919-639-4666 | SE corner of property, 10' behind front property line | 0626-91-8571.000 |

| Proposed Sign | | | |
|--|--|---|--|
| Type | Dimensions | Location / Setbacks | Illumination |
| <input type="checkbox"/> Wall <input checked="" type="checkbox"/> Ground <input type="checkbox"/> Monument <input type="checkbox"/> Directory <input type="checkbox"/> Outdoor Advertising | Overall - Width 10', 7' Length Height: 12' Electronic Message Board Square Footage 21 Total Sq. Ft 61 | 10' from front property line, over 10' side SE corner of property | <input type="checkbox"/> None <input type="checkbox"/> External <input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> Electronic Message |
| Total Length of Wall | NA | Total Size of Project / Parcel | <input type="checkbox"/> Less Than 1 Acre <input checked="" type="checkbox"/> Greater Than 1 Acre |
| Total Sq. Ft. Electronic Message Display | 21 square feet | Pole Style Ground Sign Encasement | Material Width NA |

| Current Signage | | | |
|--------------------|----------------------|------------------------------------|--|
| Current Wall Signs | Current Ground Signs | Distance Between Signs On Property | Distance Between Outdoor Advertising Signs |
| 0 | 1 | NA | NA |

| Reviewed By: | Date of Review | Review Results |
|--------------|--|--|
| Sarah Arbour | 8/1/2022 2 nd review 8/22/2022 | <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <input type="checkbox"/> More information needed |

| | |
|----------|--|
| Comments | <p>-Please note that the current ground sign will be removed on the site plan. Only one sign is permitted per street frontage. Must be removed before zoning inspection.</p> <p><u>Information Comment Only</u></p> <p>- Electronic message board portion of sign cannot change messages more than 7 times per minute. No animated presentations or animated change of frame is allowed. This will be checked as a part of the zoning inspection.</p> |
|----------|--|

Planning Services Sign Permit Review Form

Site Plan



Sign Rendering

