



# Planning Services Sign Permit Review Form

420 McKinney Pkwy  
Lillington, NC 27546  
Ph: (910) 893- 7525 opt. 2  
Fax: (910) 814-6459

Date of Submittal	Application Number	Applicant	Landowner
12/28/2023	SIGN2312-0261	Sansom Memorial Community Church Inc.	Alpha Signs and Lightning, inc.

Contact Person	Contact Number	Sign Location	PIN Number
Joseph Bain	910-635-6226	2896 Arrowhead Road. Dunn, NC 28334	1505-96-9870.000

Proposed Sign			
Type	Dimensions	Location / Setbacks	Illumination
<input type="checkbox"/> Wall <input checked="" type="checkbox"/> Ground <input type="checkbox"/> Monument <input type="checkbox"/> Directory <input type="checkbox"/> Outdoor Advertising	<b>Length</b> 12'0" 144" <b>Width</b> 8' 96" <b>Total Sq. Ft</b> 59 copy 22.87 Square ft LED Message Board	Arrowhead Rd. Setback from ROW not provided	<input type="checkbox"/> None <input type="checkbox"/> External <input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> Electronic Message
<b>Total Length of Wall</b>		<b>Total Size of Project / Parcel</b>	<input type="checkbox"/> Less Than 1 Acre <input checked="" type="checkbox"/> Greater Than 1 Acre
<b>Total Sq. Ft. Electronic Message Display</b>	22.87	<b>Pole Style Ground Sign Encasement</b>	Material --NA Width --NA

Current Signage			
Current Wall Signs	Current Ground Signs	Distance Between Signs On Property	
0	1	NA	<b>Current Sign will be removed</b>

Reviewed By:	Date of Review	Review Results
Sarah Arbour	12/28/2024	<input type="checkbox"/> Approved <input type="checkbox"/> Denied <input checked="" type="checkbox"/> More information needed

<b>Comments</b>	<p>-Please provide the distance from the sign on the property to the ROW.</p> <p>-Up to 35% of the sign copy area may be LED message board. Please reduce the proposed LED message portion of the sign to 20.4 square feet or less to meet the requirement. Currently, 22.59 feet are proposed.</p>
-----------------	---

# Planning Services Sign Permit Review Form

## Sign Rendering

