

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

March 8th, 2018

Tennie Allen Sherman
3830 US 401 N
Fuquay Varina, NC 27526

RE: Improper drain of sink drain – 3830 US 401 N -Pin# 0651-15-5580

Mr. Allen,

An on-site inspection was made on your property by an Environmental Health Specialist and observed a sink drain draining improperly onto the ground.

You are hereby notified that you are violating the Rules and Regulations adopted by the North Carolina Commission for Health Services in accordance with requirements of Article 11 Chapter 130A-335 (a) of General Statutes of North Carolina. Any person owning or controlling a residence, place of business, or place of public assembly containing water using fixtures connected to a water supply source shall discharge all wastewater directly to an approved wastewater system permitted for that specific use. A wastewater system may include components for collection, treatment and disposal of wastewater.

The sink wastewater must be tied back into the house plumbing that goes to the septic tank and system. Removal of the old sink drain pipe is required to show compliance with this letter.

You are required to correct this problem within 30 days from this date. Please be advised that any action you may take without approval does not absolve you of the responsibility for correcting this public health problem, according to health department standards. The continuation of this violation may constitute a health hazard, and if you do not comply within the allotted time frame we will be forced to obtain legal action.

We request that you contact the Health Department within 7 days in order to give us your plan of action. I can be contacted at 893-7547 Monday-Friday, from 8:00-9:00 a.m.

Sincerely,



James E Manhart III, R.E.H.S.
Environmental Health Program Specialist
Harnett County Department of Public Health

JM/kh