



Case Inspections Harnett County

Case Number: CEEH2203-0007

Description:

Opened: **3/21/2022**

Closed: **4/14/2022**

Site Address: **11 BIRCHWOOD CIR**

Last Action: **4/12/2022**

Follow up: **4/12/2022**

City, State Zip Code: **COATS, NC 27521**

Status: **CLOSED**

Applicant: **<NONE>**

Parent Project:

Owner: **STEPHENS MICHELLE OMELIA**

Contractor: **<NONE>**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	3/24/2022	3/24/2022	EH INSPECTION	Andrew Currin	FAIL	Surfacing

Notes:

Sewage surfacing at and/or near septic tank. Advised to have septic contractor pump and review for issues. No visible surfacing down drain field.

	4/13/2022	4/13/2022	EH REINSPECTION	Andrew Currin	PASS	
--	-----------	-----------	-----------------	---------------	------	--

Notes:

Homeowner called (3/30). Return called (3/31). Will be getting A&R onsite 03/31 to review for issues. Will coordinate is repair application is needed. Site visited by A&R Enterprise. D-Box collapsed. Replaced. Site dry and no failure present. (Secured)