

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

May 23<sup>rd</sup>, 2022

Donnie & Paula Maxwell  
206 Overlook Bluff  
Lillington, NC 27546

**RE: Illegal Drain Pipe- Located at 206 Overlook Bluff, Lillington**

To whom it may concern,

**An on-site inspection was made on your property 5/23/22 by an Environmental Health Specialist and observed an illegal drain pipe discharging waste water into the woods at ground surface.**

You are hereby notified that you are violating the Rules and Regulations adopted by the North Carolina Commission for Health Services in accordance with requirements of Article 11 Chapter 130A-335, 15A NCAC 18A. 1937 (a) of General Statutes of North Carolina. Any person owning or controlling a residence, place of business, or place of public assembly containing water-using fixtures connected to a water supply source shall discharge all wastewater directly to an approved wastewater system permitted for that specific use. A wastewater system may include components for collection, treatment and disposal of wastewater.

**We request that you contact the Health Department within 7 days to advise your plan of action to correct this issue. The continuation of this violation may constitute a health hazard, and if you do not comply within the allotted period, we will be forced to obtain legal action.**

I can be contacted at 893-7547 Monday-Friday, from 8:00-9:00 a.m.

Sincerely,



Mark Osborne, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health  
Environmental Health Section

MO/kh

Enclosure(s)