

www.harnett.org

Harnett County Government Complex 307 W. Cornelius Harnett Boulevard Lillington, NC 27546

> ph: 910-893-7550 fax: 910-893-9429

May 30, 2024

James Leister 22325 Jordan Road Dearborn, MO 64439-9127

RE: Failing system located at: PIN# 0526-30-1141.000

45 Remington Hill Drive Bunnlevel, NC 28323

Dear Mr. Leister:

An on-site inspection was made on your property on April 12, 2024 and May 28, 2024 by an Environmental Health Specialist and observed a failing septic system. You will need to get a septic contractor to inspect the pump system.

You are hereby notified that you are violating the Rules and Regulations adopted by the North Carolina Commission for Health Services in accordance with requirements of Article 11 Chapter 130A-335 (a) of General Statues of North Carolina. Any person owning or controlling a residence, place of business, or place of public assembly containing water using fixtures connected to a water supply source shall discharge all wastewater directly to an approved wastewater system permitted for that specific use. A wastewater system may include components for collection, treatment and disposal of wastewater.

We request that you contact the Health Department within 7 days in order to obtain an improvement permit if needed. You are required to correct this problem within 30 days from this date. You will be required to bring a recorded survey map, deed, and fill out a repair application in order to obtain an improvement permit. Please be advised that any action you may take without an improvement permit does not absolve you of the responsibility for correcting this public health problem, according to health department standards. The continuation of this violation may constitute a health hazard, and <u>if you do not comply within the allotted time frame we will be forced to obtain legal action.</u>

I can be contacted at 893-7547 Monday-Friday, from 8:00-9:00 a.m.

Mal a REds

Sincerely,

Mark Osborne, R.E.H.S. Environmental Health Specialist Harnett County Department of Public Health Environmental Health Section MO/slc

strong roots · new growth