

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

March 19th, 2025

Jose & Rosa Olivares
155 Wynnridge Dr
Angier, NC 27501

Re: Cracked PVC Pipe

Mr. Olivares

An attempt was made to evaluate your property for the purpose of a complaint received.

- ☐ 1. Use pink flags to mark property lines and irons that are
Set by surveyor need to be visible. Property lines to be marked/flagged every 50'.
- ☐ 2. Use orange flags to mark house box.
- ☐ 3. Directions not clear to property (\$25.00 fee incurred)
- ☐ 4. Property needs cleared
- ☐ 5. Driveway not shown on site plan (Revision Required)
- ☐ 6. Backhoe pits required
- ☒ **7. Other- Cracked PVC pipe from septic on surface. Have a septic contractor to the fix the septic component.**

Your application will be put on hold until the selected items above have been addressed.
Any questions I can be reached at 910-893-7547 between 8:00am -9:00am Monday-Friday.

Sincerely,



Reynold Levocz R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh

Copy: Central Permitting